


- NOTES :-
1. ALL MATERIALS TO BE MILD STEEL TO BSS 4360
  2. ALL STEEL WORK TO BE FREE FROM RUST DIRT BURRS E.T.C AND THEN GALVANIZED BY HOT DIP. PROCESS, THICKNESS AND QUALITY OF ZINC COATING TO WITHSTAND TESTS OF BSS 729.
  3. EQUIPMENT CONNECTING BOLTS NUTS AND WASHERS TO BE SUPPLIED BY THE MANUFACTURERS.
  4. BOLT THREADS TO BE RECUT WITH SLACK DIES AFTER GALVANIZING AND THEN GREASED.
  5. SUPPLIED BOLTS, NUTS, AND WASHERS TO INCLUDE 10% SPARE, AND TO CONFORM TO BSS 916
  6. FABRICATORS ARE TO DESIGNATE ALL STEEL WORK ITEM AS PER THIS DRAWING AND ARE TO PROVIDE ERECTION MARK.



APPROVED	NAME	DATE	SIGN

REF	REVISION	DATE	SIGN	CHECKED	DATE
1					
2					
3					
4					
5					
6					

**DETAILS OF 132KV STEEL TERMINAL GANTRY STRUCTURE**

**K. P. & L Co. Ltd.**  
**SK. No. 09111/A**