



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Ref: KP1/9A.3/OT/44/23-24/PM/ri

15th April, 2024

TO:

ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM NO. II FOR SUPPLY OF RUBBER GOODS FOR LIVE LINE TEAMS -
KP1/9A.3/OT/44/23-24**

Please refer to the above tender.

We make the following clarifications to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of Rubber Goods.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this clarifications, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. SECTION V- SCHEDULE OF REQUIREMENTS

The following clarifications are made on part of the tender document following prospective bidders queries.

No.	Item	Query	Responses
1	Item 4.2.10 Cordless battery operated cutting tool	Tool is not mentioned in the price schedule, although the technical specifications are mentioned in the schedule of requirement. Kindly advise if we have to quote for this item and the quantity required.	Don't quote for the cordless battery operated cutting tool.
2	Item No. 3 Rubber gloves Class Size 7.5	This size 7.5 is not available in the market, can we provide size 8 instead?	Either Size 7.5 or Size 8 can be provided for this item.
3	Item 15 face shield	We cannot find the specification for this item. The specification no. KP1/3CB/TSP/01/003-7 provided has no information about the face shield.	Appendix I – Face Shield Specifications.
4	Item 21. Insulated VDE Ratchet Ring Wrench Set-Insulated	Kindly provide specification for this item.	Attached KP1/6C/4/1/TSP/092

No.	Item	Query	Responses
			Insulated Low Voltage Tool kit - Specification
5	Slotted blankets 36" x 36" 200pairs	Slotted blankets are manufactured and sold per piece and not in pairs. Please clarify if the required quantity is 200 pieces or 400 pieces.	Slotted blankets 36" x 36" should be 200 pieces
6	Rubber Gloves 8", Class 3 - 40 pairs and 3. Rubber Gloves 7.5", Class 3 - 40 pairs	Class 3 do works up to 26KV as per the relevant standards. Please clarify if rubber gloves required are for class 3 which do works up to 26KV or class 4 which do works up to 36KV.	Rubber gloves required are for class 3 which do work for up to 26kV.

3. CHANGE OF TENDER CLOSING DATE (TENDER DATA SHEET – ITT 21.1)

The tender closing date has been extended from **Wednesday 17th April 2024** to **Thursday 25th April 2024** at 10.00am

Note: The Bid bond validity period shall be calculated as from **Wednesday 17th April 2024** Bidders who had submitted need not replace or resubmit.

All other terms and condition remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

DR. JOHN NGENO, OGW

GENERAL MANAGER SUPPLY CHAIN & LOGISTICS