



Kenya Power

Central Office – P.O. Box 30099 – 00100,
 Telephone – 254-02-3201000
 Fax No. 254-02-3514485
 Stima Plaza, Kolobot Road,
 Nairobi, Kenya

Our Ref: KPI/9A.3/OT/18/FA/21-22/PM/bkk
 Your Ref:

Date: 18th January, 2022

TO: ALL PROSPECTIVE BIDDERS

Dear Sir/Madam,

RE: ADDENDUM NO. 2 TO THE TENDER NO. KPI/9A.3/OT/18/FA/21-22 FOR SUPPLY OF LUGS, CLAMPS, JOINTS & TERMINATIONS (SPECIAL GROUPS).

Please refer to the above Tender. We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for supply of lugs, clamps, joints & terminations (special groups).

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

Below are responses to clarifications as sought by various bidders.

	BIDDERS QUERY	KPLC RESPONSE																																																
1.	Which Terminations Are Indoor And Which Outdoor In 11 And 33kv.	<p>The below will affect Section II - Tender Data Sheet, Section IV - Price Schedule, Section V -Schedule of Requirements and Delivery Schedule.</p> <table border="1" data-bbox="491 1429 1417 2038"> <thead> <tr> <th>No.</th> <th>Code</th> <th>Item Description</th> </tr> </thead> <tbody> <tr><td>1</td><td>153375</td><td>Termination 300sqmm 11kv 3/C Al Xlpe I/D</td></tr> <tr><td>2</td><td>153411</td><td>Termination 300sqmm 33kv 3/C Al Xlpe I/D</td></tr> <tr><td>3</td><td>153422</td><td>Termination 300sqmm 33kv 3/C Cu Xlpe I/D</td></tr> <tr><td>4</td><td>153435</td><td>Termination 300sqmm 11kv 3/C Al Xlpe O/D</td></tr> <tr><td>5</td><td>153459</td><td>Termination 70sqmm Lv 4/C Al Pvc O/D</td></tr> <tr><td>6</td><td>153463</td><td>Termination 185sqmm Lv 4/C Al Pvc O/</td></tr> <tr><td>7</td><td>153464</td><td>Termination 185sqmm Lv 4/C Al Pvc I/D</td></tr> <tr><td>8</td><td>153467</td><td>Termination 630sqmm 11kv S/C Al O/D</td></tr> <tr><td>9</td><td>153468</td><td>Termination 630sqmm 11kv S/C Al I/D</td></tr> <tr><td>10</td><td>153477</td><td>Termination 300sqmm 33kv S/C Al Xlpe O/D</td></tr> <tr><td>11</td><td>153481</td><td>Termination 95sqmm 11kv 3/C Al Xlpe O/D</td></tr> <tr><td>12</td><td>153483</td><td>Termination 185sqmm 11kv 3/C Al Xlpe O/D</td></tr> <tr><td>13</td><td>153484</td><td>Termination 185sqmm 11kv 3/C Al Xlpe O/D</td></tr> <tr><td>14</td><td>124152</td><td>Connector Lug Bi-Metal Crimp 70sqmm</td></tr> <tr><td>15</td><td>124178</td><td>Connector Lug Bi-Metal Crimp 120sqmm</td></tr> </tbody> </table>	No.	Code	Item Description	1	153375	Termination 300sqmm 11kv 3/C Al Xlpe I/D	2	153411	Termination 300sqmm 33kv 3/C Al Xlpe I/D	3	153422	Termination 300sqmm 33kv 3/C Cu Xlpe I/D	4	153435	Termination 300sqmm 11kv 3/C Al Xlpe O/D	5	153459	Termination 70sqmm Lv 4/C Al Pvc O/D	6	153463	Termination 185sqmm Lv 4/C Al Pvc O/	7	153464	Termination 185sqmm Lv 4/C Al Pvc I/D	8	153467	Termination 630sqmm 11kv S/C Al O/D	9	153468	Termination 630sqmm 11kv S/C Al I/D	10	153477	Termination 300sqmm 33kv S/C Al Xlpe O/D	11	153481	Termination 95sqmm 11kv 3/C Al Xlpe O/D	12	153483	Termination 185sqmm 11kv 3/C Al Xlpe O/D	13	153484	Termination 185sqmm 11kv 3/C Al Xlpe O/D	14	124152	Connector Lug Bi-Metal Crimp 70sqmm	15	124178	Connector Lug Bi-Metal Crimp 120sqmm
No.	Code	Item Description																																																
1	153375	Termination 300sqmm 11kv 3/C Al Xlpe I/D																																																
2	153411	Termination 300sqmm 33kv 3/C Al Xlpe I/D																																																
3	153422	Termination 300sqmm 33kv 3/C Cu Xlpe I/D																																																
4	153435	Termination 300sqmm 11kv 3/C Al Xlpe O/D																																																
5	153459	Termination 70sqmm Lv 4/C Al Pvc O/D																																																
6	153463	Termination 185sqmm Lv 4/C Al Pvc O/																																																
7	153464	Termination 185sqmm Lv 4/C Al Pvc I/D																																																
8	153467	Termination 630sqmm 11kv S/C Al O/D																																																
9	153468	Termination 630sqmm 11kv S/C Al I/D																																																
10	153477	Termination 300sqmm 33kv S/C Al Xlpe O/D																																																
11	153481	Termination 95sqmm 11kv 3/C Al Xlpe O/D																																																
12	153483	Termination 185sqmm 11kv 3/C Al Xlpe O/D																																																
13	153484	Termination 185sqmm 11kv 3/C Al Xlpe O/D																																																
14	124152	Connector Lug Bi-Metal Crimp 70sqmm																																																
15	124178	Connector Lug Bi-Metal Crimp 120sqmm																																																

	BIDDERS QUERY	KPLC RESPONSE
2	The lugs and ferrules for terminations and joints are crimp type or mechanical sheer head type.	Mechanical sheer head type.
3.	Do we need to supply the extra pair of lugs and ferrules in kits.	NO. Suppliers will only deliver quantities indicated in the schedule of requirements and price schedule.
4	What is submarine joint – is it for under water.	Yes, the submarine joints are meant for under water use.
5	Please provide details of ABS joint, do we need to connect it overhead in outdoor.	This is meant for the Aerial Bundled Cable which is normally 70 sq mm 3/c 11 kv Al. It is suspended just like the cable itself by the catenary wire outdoor

3. DEADLINE FOR SUBMISSION OF TENDER.

The tender closing date has been extended from 28th January 2022 to **11th February, 2022 at 2:30 pm.**

All other terms and conditions remain as per the Principal Tender Document.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



PETER MUCHORI

Ag. SUPPLY CHAIN MANAGER, PROCUREMENT