



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/35/23-24/HO/ca

22nd March, 2024

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. 5 TENDER NO. KP1/9A.3/OT/35/23-24 FOR PROCUREMENT OF ELECTRICAL EQUIPMENT FOR LESSOS 220/132KV SUBSTATION

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (Hereinafter abbreviated as the PTD) for the Procurement of Electrical equipment for Lessos 220/132kv substation

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD

2. CLARIFICATION TO BIDDERS QUERIES

The following clarification have been made with respect to item as specified below:

Query No.	Clarification sought by Bidder	KPLC Response
1.	We are requesting for clarifications in reaction to addendum 4 which has two conflicting clauses/ unclear concerning outdoor Marshalling kiosks. As per the addendum, response to query number 1 bidders shall only use specifications in the tender document and no other specification concerning the items is provided. However as per section 3 of the same addendum 4, bidders are required to also use specification document number KP1-6C 1-13-TSP-11-46 which is for indoor panels to design Outdoor marshalling kiosks among other panels. a. Are we supposed to use that specification document number KP1-6C 1-13-TSP-11-46 and fill its gtp for the	The requirement for Outdoor Marshalling Kiosks is for Lessos substation. Generally most of the aspects for this MBs is covered under KPLC document number KP1-6C-4-1-TSP-11-046-2 (for Outdoor MBs) , which is what is attached. The other unique requirements for use at Lessos substation, are contained in the main Tender document KP1/9A.3/OT/35/23-24 . In case of any conflict in the two documents, the requirements on the main tender document, takes precedence as the MBs will be used specifically at Lessos.

Query No.	Clarification sought by Bidder	KPLC Response
	<p>marshalling kios in addition to preparing a table wise statement of compliance as per response in query 1 of the addendum 4.</p> <p>b. Why is an indoor panel document being used to guide an outdoor panel yet there is a KPLC document number KP1-6C-4-1-TSP-11-046-2 specifically for designing outdoor marshalling kiosks that is not being used.</p>	

2. TENDER CLOSING DATE

The tender closing date has been extended from **27th March, 2024 to 2nd April, 2024 at 10:00am**. Opening of the tender will take place thereafter at the **Auditorium, Stima plaza** on the **same day at 10:30am**.

All other terms and conditions remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



HAROUN OTIENO

AG. GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS