



Kenya Power

Central Office - P.O. Box 30099 - 00100
 Telephone – 254 – 02 - 3201000
 Stima Plaza, Kolobot Road
 Nairobi, Kenya
 www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/44/20-21/JM/bkk

28th June, 2021

TO ALL TENDERERS

RE: ADDENDUM NO. 2 TO TENDER NO. KP1/9A.3/OT/44/20-21 FOR SUPPLY OF ABC CABLE ACCESSORIES

Please refer to the above Tender. We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Abc Cable Accessories.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT (PTD)

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATION AS SOUGHT BY VARIOUS BIDDERS

- a) Clarify some of the items that are not clear in their description including the cable range to be used with.

The items in the Schedule of Requirements are clarified as follows:

Item No.	Code	Item Description	Clarification	Specification Code
1	124152	Connector lug bi-metal crimp 70sqmm	70-120 mm ² Bimetallic lug, LV	TSP-05-012
2	N/A	Pg 16 mm glad	16-70mm ² Aluminium Alloy Parallel Groove Clamp,	TSP-05-012
3	N/A	Pg 19 mm glad	70-150mm ² Aluminium Alloy Parallel Groove Clamp	TSP-05-012
4	124202	Clamp dead end (11kv ABC)	11 kV Dead End Clamps for support catenary wire (54.6 mm ²) for 1*54.6+3*70 mm ² ABC	TSP-05-012-1
5	124214	End cap 95 - 185mm ² 11kV ABC	11kV ABC End cap 95 - 185mm ²	TSP-05-012-1
6	124203	Clamp Dead End for Neutral Carrier-ABC	50-70mm ² Dead End Clamp for Neutral Carrier-ABC, LV	TSP-05-012
7	124208	Clamp suspension neutral carrier- ABC	50-70mm ² Suspension Clamp for neutral carrier ABC, LV	TSP-05-012
8	124206	Connector insulation piercing-for ABC	IPC for ABC to ABC Tee Connection (main: 25-120 mm ² ; Tap: 4-35 mm ²)	TSP-05-012
9	101066	Insulating piercing conn. 4x35- 70mm ²	Provide as Item 8 (IPC for ABC to ABC Tee Connection (main: 25-120 mm ² ; Tap: 4-35 mm ²))	TSP-05-012
10	124213	Clamp service cable (s/ph)-ABC	House service strain clamp, Single phase (10-16 mm ²) for ABC	TSP-05-012

Item No.	Code	Item Description	Clarification	Specification Code
11	124211	S Connector Insulation Piercing A//AB-AC	Insulation Connector Piercing for Aluminium to ABC ((main: 25-120 mm ² ; Tap: 25-95 mm ²)	TSP-05-012
12	124235	Conn. Par.groove al/al 95-185mm 11kv ABC	70-150 mm ² Parallel Groove Clamps	TSP-06-036-1
13	124257	Insulator Piercing Connector 120/16-25mm ²	IPC for Customer/Street Lighting service (main: 16-120 mm ² ; Tap: 1.5-25 mm ²)	TSP-05-012
14	124263	Cable Ties 95-185mm ² 11KV ABC	Cable Ties 95-185mm ² 11KV ABC	TSP-05-012-1
15	124225	Insulated Crimped Joints ABC	Insulated Crimped Joints ABC for 3X70mm ² 11kV ABC cable	TSP-05-012-3

b. Provide specifications for the following: Pg 16 mm glad, Pg 19 mm glad, Clamp service cable(s/ph)-ABC, Insulated Crimped Joints ABC, Conn. Par. groove al/al 95-185mm 11kv ABC & S Connector Insulation Piercing A//AB-AC:

The items' specifications are as shown above in Clarification to Query 1 above. The specifications are attached with their details as follows:

No.	Specification Code	Title	Date Of Issue
1.	TSP-05-012	Specification for Aerial Bunched Cables (ABC) Accessories - Low Voltage Overhead Line Fittings (ABC)	Issue 2, Rev 0 2016-02-04
2.	TSP-05-012-1	Accessories for Aerial Bundled Conductors (ABC). Part 1: 11KV ABC Accessories — Specification	Issue 2, Rev 1 2017-12-08
3.	TSP-05-012-3	Specification for Cold Shrinkable Straight Through Joints and Terminations for 11kV Aerial Bundled Cables	Issue 1, Rev 0 2013-09-16
4.	TSP-06-036-1	Specification for Overhead line fittings Part 1: Fittings for 10-300 mm ² Conductors	Issue 2, Rev 1 2015-09-17

b) Clamp Dead End for Neutral Carrier ABC – is heat shrinkable required?

Bidders should Provide as stated in the specification.

c) Please provide us with cable sizes for the item codes 4, 5, 6, 7, 8, 10, 11, 14 & 15:

The sizes required are now clarified in Query 1.

d) For Item 15 (Insulated Crimped Joints ABC), please confirm the cable cross-section for LV ABC required for this application.

This is now clarified in Query 1.

3. DEADLINE FOR SUBMISSION OF TENDER

The bidders are required to take note that the tender closing date has been extended to **9th July, 2021 at 10:00 am**. Those bidders who had submitted the bid securities need not to extend as their validity will be considered from the initial closing date.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC


Dr. JOHN NGENO

GENERAL MANAGER SUPPLY CHAIN & LOGISTICS.