



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/44/20-21/JM/bkk

08th July, 2021

TO ALL TENDERERS

RE: ADDENDUM NO.3 TO TENDER NO. KP1/9A.3/OT/44/20-21 FOR SUPPLY OF ABC CABLE ACCESSORIES

Please refer to the above Tender. We make the following clarifications and amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Abc Cable Accessories.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT (PTD)

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATION AS SOUGHT BY A BIDDER.

The items in the Schedule of Requirements are clarified as follows:

Code	Item Description	Query	Clarification	Specification Code
124152	Connector Lug bi-metal crimp 70sqmm	70-120mm Bimetallic Lug LV Which specific size is required as crimp bimetallic Lugs are not range taking.-	Suitable for 3X70mm ² ABC cable	TSP-05-012
124202	Clamp Dead-End (11KV ABC)	11KV Dead-End Clamps for supporting Catenary wire (54.6sqmm) for 1*54.6+3*70mm ABC. Is this requirement for 11KV ABC or LV ABC as Catenary wire defined in the clarification is for LV ABC Cable?-	Catenary Wire size is 50mm ² as per specification and for 11kv ABC Cables as per specification KP1-6C-4-1-TSP-05-012-1 clause 4.2.2 and 4.3.1	TSP-05-012

3. DEADLINE FOR SUBMISSION OF TENDER

The bidders are required to take note that the tender closing date has been extended to **19th July, 2021 at 11:00 am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

JANE MUIGAI
SUPPLY CHAIN MANAGER, (PROCUREMENT)