



Kenya Power

*The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road*

Our Ref: KP1/9A.3/OT/12/23-24

10th November, 2023

TO ALL PROSPECTIVE TENDERERS

RE: ADDENDUM NO. 5 TO THE TENDER NO. KP1/9A.3/OT/12/23-24 FOR SUPPLY OF EMERGENCY RESTORATION TOWERS (ERTs) AND GALVANISED STEEL STRUCTURES FOR IMPLEMENTATION OF PREMIUM CUSTOMERS SCHEMES AND FOR VARIOUS PRIMARY AND SECONDARY SUBSTATION

The following amendments are made to the specified provisions of the Tender document for Supply of Emergency Restoration Towers (ERTS) and Galvanized Steel Structures for implementation of premium customer's schemes and for various 220/132/66/33/11kv Substations for October 2023

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION

The following responses are made to clarifications sought on various issues on the tender document.

Clause No./ Query No.	Clarification sought by Bidder	KPLC Response
1	Whether the packaging will be 20Ft container per tower	The supplier to propose and utilize suitable packaging for the goods.

Clause No./ Query No.	Clarification sought by Bidder	KPLC Response
2	Whether the containers will be part of the supply and will be used for storage(Not to be returned to shipping line)	Containers to be part of supply and remain as KPLC property.
4.2.2.5	The structure shall include an integral rail system, which requires the allowed sliding gin pole and the safety devices to slide from the bottom to the top of the tower without any interruption or disassembly. The Same functionality can be achieved without rail system. Kindly confirm that we can offer without the rail system as the design has provided a mean of achieving the required functionality without the rail system	Bidders to comply with the requirement. Alternative Tenders shall not be considered.
4.2.2.4	All components shall be lightweight and none to exceed 150kgs... the offered solution is designed to be transported by hand as per the requirement but exceed the weight of 150kgs which is within the design standard ASLE10-97 of less than <200kgs	Bidders to comply with the requirement. Alternative Tenders shall not be considered.

3. TENDER CLOSING DATE

The tender closing date remains to be 14th November 2023 at 10:00am, opening of the Tender will take place thereafter at the Auditorium, Stima Plaza on the same day at 10.30am.

All the other terms and conditions remain as per the tender document.

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY LIMITED.



Dr. JOHN NGENO
GENERAL MANAGER, SUPPLY CHAIN