



Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/49/20-21/PM/JM/jmk

28th July 2021

TO: ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO.5 TO THE TENDER NO. KP1/9A.3/OT/49/20-21 FOR SUPPLY OF CURRENT TRANSFORMERS (CTS), VOLTAGE TRANSFORMERS (VTS), CAPACITOR VOLTAGE TRANSFORMERS (CVTS) AND AIR BREAK SWITCH.

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of Fuse Cutouts.

1. Relationship with the Principal Tender Document

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. Clarifications

Subjected to earlier clarifications provided in Addendum 4, the following additional clarifications are provided;

Ratings for 36kV Current Transformer Type IV:

Type of CT	Type IV
Rated Primary Current	100A
Rated Secondary Current	1A
Rated short circuit withstand current and duration.	31.5 kA, 3 seconds
Rated Dynamic Current	79kA

Type of CT		Type IV
CT Ratio		100-50/1-1
Accuracy class and rated burden	Core 1	Class 5PR20, 15VA, $V_k \geq 450V$
	Core 2	Class 0.2, 15VA, $IFS \leq 10$, $R_{ct}@75^\circ C \leq 7.5 \Omega$
	Core 2	Class 0.5, 30VA, $IFS \leq 10$, $R_{ct}@75^\circ C \leq 7.5 \Omega$
Burden at all Ratios		Minimum Burden at any Ratio is 15VA
Rated Temperature of Equipment		-5°C to +50°C

3. Tender Closing Date

The closing date has been extended from 29.07.2021 to 05.08.2021 at 10.00am.

NB: Bid Security's validity period shall count from Tuesday, 20.07.2021 and NOT the new Tender closing date – as earlier communicated.

All other terms and condition remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



RUTH OYILE

AG. SUPPLY CHAIN MANAGER, PROCUREMENT.