



Central Office Kenya Power 1100,
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road,
Nairobi, Kenya

Our Ref: KPI/9A.3/OT/10/FA/21-22/PM/hm

Date: 27th January, 2022

Your Ref:

TO: ALL PROSPECTIVE BIDDERS

Dear Sir/Madam,

RE: ADDENDUM NO. 5 TO THE TENDER NO. KPI/9A.3/OT/10/FA/21-22 FOR SUPPLY OF MEDIUM VOLTAGE (MV) AND HIGH VOLTAGE (HV) FITTINGS

Please refer to the above Tender.

We make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Medium Voltage (MV) and High Voltage (HV) fittings.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. AMENDMENTS TO THE TENDER DOCUMENT

No	As per uploaded Tender Document	Amendment
1.	27. Termination for Convenience GCC (clause 27.1) 27.1 KPLC, by written notice sent to the Supplier, may terminate the Contract, in whole or in part, at any time for its convenience. The notice of termination shall specify that termination is for KPLC's convenience, the extent to which performance of the Supplier under the Contract is terminated, and the date upon which such termination becomes effective	Amended as follows: 27.1 Termination for Convenience shall be subject to Regulation 141(5) of the PPADR 2020
2.	Part 1 - Preliminary Evaluation Criteria under ITT 29.2. These are mandatory requirements	Addition to Preliminary Evaluation: 3.1.15 Where tenderer is a JV: Submission of duly filled, signed, and stamped JV Agreement Form, letter of intent, and

		Power of Attorney for the JV's representative
No	As per uploaded Tender Document	Amendment
3.	<p>3.1.5</p> <p>d) Names with full contact as well as physical addresses of previous customers of stay accessories, reference letters or completion certificate issued within the last four years confirming completion of orders on schedule by tenderer from KPLC or at least four (4) other previous customers of stay accessories (New manufacturers will be exempted from this requirement but subjected to all other clauses in this section)</p>	<p>Part 1 - Preliminary Evaluation Criteria under ITT 29.2.</p> <p>Amended as follows:</p> <p>3.1.5</p> <p>(d) Names with full contact as well as physical addresses of previous customers of authorizing manufacturer, reference letters or completion certificate issued within the last four years confirming completion of orders on schedule by tenderer from KPLC or at least four (4) other previous customers of the authorizing manufacturer.</p>

The tender closing date remains 8th February 2022.

Kindly adhere to the changes

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



PETER MUCHORI

Aq. SUPPLY CHAIN MANAGER, PROCUREMENT