

The Kenya Power & Lighting Co. Ltd.

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road

Our Ref: KP1/9A.2/OT/068/ICT/23-24/JN/rmh

19th March, 2024

ALL PROSPECTIVE BIDDERS.

Dear Sir/Madam,

ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.2/OT/068/ICT/23-24 FOR SUPPLY AND INSTALLATION OF AIR-CONDITIONERS FOR SCADA CONTROL

The following clarifications are made to the specified provisions of the Tender document.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION

The following clarifications were made on the tender document and shall be deemed to form the Addendum

No.	CLARIFICATION SOUGHT	RESPONSE
1.	The following mention documents are missing,	3.1.2 (f) This is the same as tenderer information form provided in the tender
	3.1.2 f. Form EL1 1.1 - Tenderer Information Sheet	document. 3.1.8 You are required to provide
	3.1.8 Duly filled Form EXP 4.1 and names with full contact as well as physical addresses of previous customers of similar works with reference letters from at least two (2) previous customers.	evidence of similar works carried out inform of a contract and completion certificates.
2.	Kindly clarify on the parts that will be required for the Denco Units on the BoQ	Denco service parts include; 1. refrigerant, 2. fans, 3. cooling coils and 4. any consumables required in the course of normal service.

3. CLOSING DATE

The Tender closing date remains 25th March, 2024 at 10.00 am.

All other terms and conditions remains as per the Principal Tender Document (PTD)

Yours faithfully,

For: THE KENYA POWER & LIGHTING COMPANY PLC

DR. JOHN NGENO, OGW

GENERAL MANAGER, SUPPLY CHAIN AND LOGISTICS