



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/27/FA/21-22/AE/jk

6th April, 2022

TO ALL TENDERERS

RE: ADDENDUM NO. 2 TO TENDER NO.KP1/9A.3/OT/27/FA/21-22 FOR SUPPLY OF MINIATURE CIRCUIT BREAKERS (MCBs)-SPECIAL GROUPS.

Please refer to the above Tender. We make the following amendments to the Principal Tender Document (hereinafter abbreviated as the PTD) for the Supply of Miniature Circuit Breakers (MCBs)-Special groups.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT (PTD)

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATION TO QUERIES

	BIDDERS QUESTIONS	KPLC RESPONSE
1	Are the lots categorized per each special group or all lots are open to all special groups.	Lots are open to all special groups.
2	Is a manufacturer's authorization form required for this tender?	Yes. It is a Mandatory requirement
3	Considering the document has different sections with primary procurement section having almost similar documents with secondary procurement section forms. Are the forms under secondary procurement supposed to be filled at this stage?	Fill forms under Primary Procurement only.
4	From the technical specifications given, there is TYPE B, C & D. It is indicated that the exact type will be indicated in the schedule of requirements of the tender document. Kindly note that the same has not been indicated in the schedule of requirements. KINDLY CLARIFY THE TYPE OF MCB REQUIRED	Tripping characteristics of MCB – Type C

	BIDDERS QUESTIONS	KPLC RESPONSE
5.	<p>From the specifications given, the IP rating is given as IP55. However, as per the IEC 60529, the rating for MCBs is IP20.</p> <p>However for IP 55 rating, the MCB can be supplied with an encloser with IP55 rating. However, the additional encloser hasn't been mentioned in the specifications.</p> <p>Kindly clarify on the above.</p> <p>KINDLY CLARIFY ON THE IP RATING OF THE MCBs.</p>	<p>Clause 4.2.1.13 – Table 1 Degree of protection amended to IP 20</p>

3. SAMPLES

Bidders shall submit 2pcs of Samples on or before tender closing date. Bidders to drop their samples at 3rd floor Supply Chain office.


4. TENDER CLOSING DATE

The new tender closing date is Wednesday 27.04.2022.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



ASHENE ESHITUBI

AG.GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS