



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.1A/OT/015/20-21/JM/ama

17th May, 2021

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. I TO THE TENDER NO. KP1/9A.1A/OT/015/20-21 FOR SUPPLY OF PROTECTION RELAYS AND TOOLS

Please refer to the above tender.

We make the following amendment to the above Principal Tender Document (*Hereinafter abbreviated as the PTD*) for the supply of protection relays and tools.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

The following response is made to clarification sought on issue in the tender document and shall be deemed to form the addendum;

No	Query	RESPONSE
1.	Q1. Specification documents at point "4.4.27 – Annunciator Relay Type 1 -vii" they have mentioned the requirement of at least 36 element instead of 32 element which is on the BOQ.	For the Requirements of this particular tender, Clause 4.4.27- Annunciator Relay type 1, sub-clause (vii) of the Technical Specifications, is amended to read "The single relay shall be equipped with at least thirty-two (32) separate alarm elements in a single casing. Each alarm to be independently programmable"

2.	Q2. Specification KP1/6C/4/1/TSP/13/001; Clarify if you will need laptops (if YES please specify the quantity needed) for items under the specification KP1/6C/4/1/TSP/13/001.	In this tender, laptops are Not required.
----	--	---

3. CHANGE OF TENDER CLOSING DATE

The tender closing date has been extended from **19th May, 2021** to **3rd June, 2021**.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



JANE MUIGAI

SUPPLY CHAIN MANAGER, PROCUREMENT.