



The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road

Our Ref: KP1/9A.2/OT/060/ICT/22-23/JN/rmh

19th May, 2023

THE PROSPECTIVE BIDDERS,

Dear Sir/Madam,

ADDENDUM NO. 1 TO THE TENDER NO. KP1/9A.2/OT/060/ICT/22-23 FOR UPGRADE OF UPS SYSTEM IN LESSOS, KIGANJO, LANET AND MAMBO LEO CONTROL CENTERS

The following clarifications and amendments are made to the Principal Tender document (herein abbreviated as PTD) for Upgrade of UPS System in Lessos, Kiganjo, Lanet and Mambo Leo Control Centers.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATION

The following clarifications were made on the tender document and shall be deemed to form the Addendum

No.	CLARIFICATION SOUGHT	RESPONSE
1.	The warranty Period	Warranty period is 12 months not 18 months
2	Installation, testing & commissioning of SMF (seal maintenance free) Battery Banks for 30 kVA UPS for providing backup time of 60 mins at full load & battery cabinet. The bidder is obligated to proof the back up time of 60 minutes for each UPS in RPA by using a load bank test to guarantee that each UPS will run for 60 minutes. For Kiganjo Control Center.	The correct quantity is 2 Sets and not 1 Set

3. TENDER CLOSING DATE

The Tender closing date and time remain the same as the one indicated on the KPLC tendering portal.

All other terms and conditions remains as per the Principal Tender Document (PTD)

Yours faithfully,

For: **THE KENYA POWER & LIGHTING CO. PLC**



DR. JOHN NGENO
GENERAL MANAGER, SUPPLY CHAIN AND LOGISTICS