

**Central Office** – P.O. Box 30099, Nairobi, Kenya  
 Telephone – 254-02-3201000  
 Fax No. 254-02-3514485  
 StimaPlaza, Kolobot Road  
 Nairobi, Kenya

**Our Ref:** KP1/9A.2/OT/018/NM/20-21/JM/mm

Friday May 28<sup>th</sup>, 2021

TO: ALL PROSPECTIVE BIDDERS

**Dear Sirs/ Madams:**

**RE: ADDENDUM NO. 2 TO THE TENDER NO. KP1/9A.2/OT/018/NM/20-21  
 FOR SUPPLY OF CABLE FAULT LOCATION AND VERY LOW FREQUENCY EQUIPMENTS**

Following the advertisement of the above tender we have found it necessary to make amendment and clarifications to the Principal Tender Document (*hereinafter abbreviated as the PTD*) Supply of Cable location and very low frequency equipment's April, 2021

**RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the Principal Tender Document.

**1. APPENDIX TO INSTRUCTIONS TO TENDERS**

The Appendix to Instructions to tenderers has been amended as follows.

No	ITT Reference Clause	Particulars of Appendix
1.	<b>3.11.2 Tender Prices</b>	Prices quoted shall be <b>DDP VAT INCLUSIVE</b> . Delivered Duty paid.
2.	<b>3.12.2 Tender currencies</b>	For goods that the Tenderer will provide from within or outside Kenya, the prices shall be quoted in Kenya Shillings, <b>KSHS</b> . The currency must be indicated clearly on the Price Schedule of Goods.
3.	<b>3.17.1 Tender Security</b>	Tender security shall be an amount of Kshs, each is as follows: 1.Cable Fault Location Equipment.KSHS. 700,000/- 2.Very low frequency Equipment(VLF) KSHS. 160,000/- in form of Bankers guarantee. The Original Tender Security in an envelope clearly labelled with

		<i>the tender number &amp; name, shall be deposited in the <b>Tender Security Box on 3<sup>rd</sup> Floor Supply Chain Reception on or before the opening date</b></i>
4	<b>7.24.2</b> Warranty of 36 months. Please confirm if this is valid	Yes it is valid and shall remain <b>36 months</b> as indicated.

## 2. CLARIFICATION ON TECHNICAL SPECIFICATION

No	Requested Clarification	Our Response
1	Clause 3.15.4 Type test reports. Manufacturer can only get older than 5 years	While submitting the type test reports let them be less than 10 years
2	Clause 7.27 Language and Law (Tender Document) Confirm if a neutral place of Law for foreign bidders ( outside Kenya) is acceptable?	Laws of Kenya shall apply and any dispute resolution shall be carried out within the territory of kenya before a recognized dispute resolution body.
3	Clause 1 Scope of the Tender Specifications. There is a list of Items ranging from 1.2 (a) up to 1.2 (i) Clarify the items required to be given the cost/ quoted	The items required in this Tender from the Specifications are:- 1. Clause 4.2.1 Portable Cable fault location Equipment with pre-location and DC pressure test up to 32 KV 2. Clause 4.2.10 VLF pressure test with Tan delta up to 44 KV which is portable.
4	Specify the voltage rating and functionalities of the VLF required as provided in the specifications	From the specifications refer to the Scope Clauses 1.2(h), 1.4 and 1.5. For Specific requirements refer to Clause 4.2.10 for VLF up to 44 Kv, and sub sequent Clauses 4.2.10.1, 4.2.10.2, 4.2.10.3, 4.2.10.4 and 4.1.10.5 for details of the VLF equipment required in this particular tender. VLF testing Equipment of up to 44 kv are the ones required in this tender.
5	Spec 4.2.11.11.1 - The PRT system is required to be integrated in the VLF. Would an external & portable PRT be acceptable?  Spec 4.2.11 - Since the VLF and its components shall weigh more than 250 KG, is there a requirement for it to be on wheels or mobile?	The PRT (Pulse Reflection Test system) is a computer program and not a physical device to be connected to the VLF instrument.  Clause 4.2.11.11 of the specifications cl No where in the specification does it state whether the vlf is required to be on wheels or mobile but the equipment must be portable.
6	Specify the options accessories	From the specifications Refer to Clauses 1.2 (a),

	and additional equipment required with CFL as given in the specifications.	and Clause 1.3 in the Scope. From Specific Requirement refer to Clause 4.2 and subsequent Clauses 4.2.1, 4.2.1.1, 4.2.1.2, 4.2.1.3, 4.2.1.4, 4.2.1.5, 4.2.1.6, 4.2.1.7 and 4.2.1.8 which gives the details of the CFL equipment required in this tender. The CFL Equipments are portable with pre-location and DC pressure test 32 KV
--	--	---

### **CHANGE OF CLOSING DATE**

The tender closing date of **31<sup>st</sup> May 2021** has been changed to Tuesday **15<sup>th</sup> June 2021 at 11.00 am**, to allow prospective bidders sufficient time to respond.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY PLC**



**JANE MUIGAI**

**SUPPLY CHAIN MANAGER, PROCUREMENT**

