



Kenya Power

Central Office - P.O. Box 30099 - 00100

Telephone – 254 – 02 - 3201000

Stima Plaza, Kolobot Road

Nairobi, Kenya

www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/47/20-21/JN/jk

June 28, 2021

TO ALL TENDERERS

RE: ADDENDUM NO. 3 TO TENDER NO.KP1/9A.3/OT/47/20-21 FOR SUPPLY OF SMART METERS

Please refer to the above Tender. We make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Supply of Smart Meters.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT (PTD)

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2. AMENDMENT TO CLAUSE 4.2.2 COMMUNICATION SPECS- KP1/13D/4/1/TSP/14/11-05
4.2.2.6 OF SPECS KP1/13D/4/1/TSP/14/11-05**

Clause 4.2.2.6 The Meters shall have a modular design and have a GPRS communication module and also support other communication modules and the point at which it is placed shall be sealable. The Meter shall be able to communicate with a remote central system using a plug in modem/module, through the GPRS 3G networks and higher.

The **clause 4.2.2.6** has been amended to read: The Meters shall have a modular design and have a plug in GSM 4G communication modem/module and shall support other communication modules as per **clause 4.2.2.9** and the point at which it is plugged in shall be sealable. The Meter shall communicate with a remote central system. The 4G modem shall support all the GSM technologies.

3. DEADLINE FOR SUBMISSION OF TENDER

The bidders are required to take note that the tender closing date remains **Wednesday, 7th July 2021 at 10:00am.**

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



DR JOHN NGENO

GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS