



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/40/22-23/JN/em

13th June, 2023

TO: ALL PROSPECTIVE BIDDERS

RE: ADDENDUM No. IV, TENDER FOR SUPPLY OF SMART LARGE POWER 3 / PHASE METERING UNITS. KP1/9A.3/OT/40/22-23

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of concrete poles.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

KPLC wish to respond to clarifications that have been sought as follows;

No.	Clarification Sought	KPLC Response
1.	In the clause 4.5.7 Auxiliary Power supply of 12kV outdoor protection and metering breaker units specification (KP1/6C/4/1/TSP/14/018), It mentioned the requirement for Auto-recloser, but the tender is for outdoor metering unit, please clarify	Please Comply with Specification – Expected is supply of unit with PCTC, Circuit breaker, SMART meter and Protection Relay
2.	In the clause 4.5.4.4 Table 3, the burden for the VT is 150VA per phase, based on our manufacturing experience it is very high for this item, Even	Please Comply with Specification

	though this is a tailored product please clarify whether it is right?	
3.	The structure of addendum 1 created confusion on the documents that are supposed to be filled by for each item. For example concerning this item, document number KP1/6C/4/1/TSP/14/018 has all the specifications for individual components in it, however based on the addendum its like bidders are being guided to fill separate documents for CTs i.e. document KP1/6C/4/1/TSP/006-2 which we think it's a mistake. Kindly clarify	For all items the meter Specification is KP1/13D/4/1/TSP/14/020– while for item 11kV outdoor metering unit – the document KP1/6C/4/1/TSP/14/018 covers all the other parts
4.	We have also noted that addendum1 requires all bidders to fill meter specification document number KP1-13D-4-1-TSP-14-020, however based on our understanding meters are procured separately by KPLC, kindly advice if we are the ones to supply that meter for the 11kv outdoor metering unit.	Each item will be supplied with the SMART meter as per Specification KP1/13D/4/1/TSP/14/020 and wired in the enclosure.

3. CLOSING DATE

As a result of the above clarifications, the tender closing date has been changed from **Thursday 15th June, 2023 to Tuesday 20th June, 2023** to enable the prospecting bidders to have sufficient time to prepare their bids.

All other terms and conditions remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

Dr. JOHN NGENO

GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS