

Central Office – P.O. Box 30099, Nairobi, Kenya
 Telephone – 254-02-3201000
 Fax No. 254-02-3514485
 StimaPlaza, Kolobot Road
 Nairobi, Kenya

Our Ref: KP1/9A.1A/OT/015/20-21/JM/js

16th June 2021

TO: ALL PROSPECTIVE BIDDERS

1. RE: ADDENDUM NO. V TO THE TENDER NO. KP1/9A.1A/OT/015/20-21 FOR SUPPLY OF PROTECTION RELAYS AND TOOLS

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of Relays and tools.

2. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

3. CLARIFICATION FOR RELAYS

	<u>Query</u>	<u>KPLC Response</u>
1	There is a discrepancy between the warranty period in the new protection relay specifications and the warranty period stated in the tender document (special condition of contract). Please advise which warranty periods to follow	The warranty is Sixty (60) months or five years
2	The new specification didn't define which relay is backup over current & earth fault relay as required in the schedule of requirement. Please advise which is the correct relay to quote from the specification	In the New specifications, the Feeder Protection Relay replaces the Three Overcurrent and Earth fault Relays in the old specifications.

4. CLOSING DATE

The closing date remains **23.06.2021 at 10.00am.**

All other terms and condition remain the same.

Kindly adhere to the changes.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



JANE MUIGAI

SUPPLY CHAIN MANAGER, PROCUREMENT.