



Kenya Power

Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/36/20-21/JM/hm

13th May 2021

TO: ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. 5 TO THE TENDER NO. KP1/9A.3/OT/36/20-21 FOR SUPPLY OF 220KV, 66KV, 33KV AND SURGE ARRESTORS.

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of Circuit Breakers and Surge Arrester.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS ON SECTION IV –EVALUATION CRITERIA

KPLC makes the following clarification against prospective bidders' queries: -

A. Technical specifications

Clause Ref. No.	Prospective Bidder's Query	KPLC Response
4.2.3.1	33kV Circuit breaker – Spec. No KP1/13D/4/1/TSP/11/115 Short circuit Current (STC) rating is specified as 31.5kA/3sec Short circuit making current is specified as 63kA Bidders: As per IEC, short circuit Making Current is	Adhere to specifications. It should therefore imply that the making current is 79kA (2.5x31.5kA)

Clause Ref. No.	Prospective Bidder's Query	KPLC Response
	2.5 times of short Time breaking current. Request confirm the exact requirement of short circuit current.	

Important notes:

- (i) That revision of KPLC standards is informed principally by prevailing network circumstances and future projections of network parameters. As such, raising of the Circuit Breaker STC requirement from 25kA to 31.5kA was meant to cater for the rising fault levels on 33kV nodes occasioned by the changes on the grid.
- (ii) STC requirements inform the making current requirements and not the vice versa. Moreover, the specified making current is based on the theoretical instant fault current, which can rise to twice the symmetrical fault level. Hence, the specified STC should inform making current at 79kA.

B. DAP Terms of Supply for Foreign Bidders

The Supplier shall be responsible for the cost of goods, freight, customs duty and other taxes, inland transportation in the Purchaser's Country to convey the Goods to their final destination (KPLC Nairobi South). However, the 16% Value Added Tax shall be reimbursed after delivery and presentation of invoice for payment. The claim for VAT refund must be accompanied by an original KRA receipt/bank-slip, customs entry form, and Bill of Lading showing KPLC as the consignee of the goods.

3. SECTION IV –EVALUATION CRITERIA AMENDMENTS.

a) Table 2 (i.e. Capacity Declaration Form) is hereby amended as follows: -

Capacity Detail	KPLC Requirement		Manufacturer to indicate	Meets capacity (Yes / No)
Quality Certifications	Valid ISO 9001:2015, etc.			
Testing & Calibration Lab	ISO/IEC 17025			
Manufacturing Experience (Date plant was established)	Minimum 10 years			
Monthly Production Capacity	Brief Description	Quantity (Pc) (Minimum)		
	220kv circuit breakers	15		
	132kv circuit	20		

Capacity Detail		KPLC Requirement		Manufacturer to indicate	Meets capacity (Yes / No)	
	breakers					
	66kv circuit breakers	25				
	33kv circuit breakers	40				
	220kv surge arresters	20				
	132kv surge arresters	30				
	66kv surge arresters	50				
	33kv surge arresters	500				
Quality Assurance Plan (QAP)		Attach QAP				
Previous completed orders of similar goods supplied in the last four years:		Minimum 4				
Customer's Name	Order No.	Order Date	Product Description	Order Quantity	Export Country	% Delivered
1.						
2.						
3.						
4.						

The Tender closing date remains **20th May 2021 – 1000hrs** as per addendum No.4.

All other terms and conditions remain the same.

Please adhere to the changes.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

JANE MUIGAI

SUPPLY CHAIN MANAGER, PROCUREMENT

