



Central Office – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000  
Fax No. 254-02-3514485  
Stima Plaza, Kolobot Road  
Nairobi, Kenya

**Our Ref:** KP1/9A.3/OT/13/21-22/PM/jnk

**15<sup>th</sup> July 2022**

TO:

ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM NO. 2 TO TENDER NO. KP1/9A.3/OT/13/21-22 SUPPLY OF CURRENT TRANSFORMER(CTS) & SWITCHGEARS**

Please refer to the above tender.

We make the following amendment to the above Principal Tender Document (*Hereinafter abbreviated as the PTD*) for the supply of current transformers (CTS) and switch gears.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2. CLARIFICATIONS**

The following responses are made to clarification sought on issues in the Specifications and shall be deemed to form the addendum;

No.	Technical Query	KPLC Response
<b>Q1</b>	<b>33KV Current Transformers</b>  We have checked the standard of IEC61869-1, the general standard of transformer, items No 6.7 mentions that mechanical test is only applicable to products with voltage level of 72.5kV and above, and items No 6.11.2 mentions that magnetic compatibility test is applicable to transformer products with $U_m \geq 123kV$ , and there is no requirement for 33kV CT. Kindly clarify.	According to IEC 61869-1:2007 and IEC 61869-2:2012, the magnetic compatibility test (EMC) and Mechanical test are not applicable for 33kV CT

### **3. CHANGE OF TENDER CLOSING DATE**

The tender closing date has been extended from **21<sup>st</sup> July, 2022** to **28<sup>th</sup> July, 2022** at **10.00am**.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY PLC**

**PETER MUCHORI**

**AG. SUPPLY CHAIN MANAGER, PROCUREMENT.**