



Kenya Power

Central Office - P.O. Box 30099 - 00100
Telephone – 254 – 02 - 3201000
Stima Plaza, Kolobot Road
Nairobi, Kenya
www.kenyapower.co.ke

Our ref: KP1/9A.2/OT/010/21-22/AE/Ilk

16th March 2022

Your ref:

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO.1 TO TENDER NO.KP1/9A.2/OT/010/21-22 ON PROVISION OF ONE (1) YEAR SERVICE AND MAINTENANCE CONTRACT FOR NINETEEN STAND-BY GENERATORS

Please refer to the above Tender.

Following requests for clarifications arising from prospective bidders and at our own initiative, we wish to make the following amendments to the Principal Tender Document (*hereinafter abbreviated as the PTD*) for Provision of One (1) Year Service and Maintenance Contract for Nineteen Stand-By Generators.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this addendum shall be deemed to have been incorporated in and shall be read and constructed as part of the PTD.

2. CLARIFICATIONS

The following clarifications have been made as hereunder:

No.	Reference	Response
1.	Tender Submission Checklist	Item 18 (Price Schedule) and 21 (Priced Bill of Quantities) shall be read to mean one and the same item.
2.	Maintenance Schedules	A major service is to be undertaken after 200 operating hours or 12 months (whichever is earlier) with an additional mandatory three quarterly inspections
3.	Spare parts	The spare part list provided in the tender document is not conclusive. The bidders are allowed to add as much spares as they deem fit. The quote for the spares shall not form the final quote due to the nature of the list which may vary from bidder to bidder. However, the prices quoted must be within the market price.

No.	Reference	Response
3.	Site visits	The sites are open to visit if a bidder so desires. Request for a visit is to be made through the e-mail addresses on the cover page of the tender document and a link person would be provided for the particular area requested.
5.	Award Criteria	The award criteria has been amended to read ' <i>The award shall be to the bidder with the lowest evaluated price cumulatively in categories 1&2. The spares list for the awarded bidder shall be adopted</i> '
6.	Form SD2: No.1 line 3	Clause No.1 line three has been amended to read ' <i>Provision of One(1) Year Service and Maintenance Contract for Nineteen Stand-By Generators</i> '

2. CLOSING DATE

The closing date has been extended to Wednesday, 30th March 2022 at 10.00 a.m. The venue shall be at Stima Plaza, Auditorium or as shall be otherwise advised.

All other terms and conditions remain as per the Principal Request for Proposal.

Yours faithfully,

For: **THE KENYA POWER & LIGHTING CO. PLC**



PETER MUCHORI
Aq. SUPPLY CHAIN MANAGER, PROCUREMENT