

Central Office – P.O. Box 30099, Nairobi, Kenya
 Telephone – 254-02-3201000
 Fax No. 254-02-3514485
 StimaPlaza, Kolobot Road
 Nairobi, Kenya

Our Ref: KP1/9A.3/OT/014/22-23 /PM/ri

20th February 2023

TO: ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. II TENDER FOR KP1/9A.3/OT/014/22-23 FOR SUPPLY OF RUBBER GOODS FOR LIVE LINE TEAMS

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of Supply of Rubber Goods for Live Line Teams.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. TECHNICAL SPECIFICATIONS

Following the pre-bid meeting that was held on 16th February 2023, we wish to clarify the following issues as follows:

No.	Prospective Bidder's Query	KPLC Response
1.	<u>FACESHIELD</u> - No specifications provided for face shield, the one attached is for eyes protection.	Shall be provided as appendix I .
2.	<u>RUBBER GLOVES</u> : The gloves size specified for (size 7.5") is not available in the market.	To provide size 8 or Lower for the same class of Rubber insulating glove
3.	<u>CONDUCTIVE SUITS</u> : The specific sizes of the suits are not provided for yet the cost of a suit is affected by the size.	Sizes: Large- 12 Pcs Extra Large 8 Pcs
4.	<u>BLANKETS</u> : KPLC to confirm if bidders are quoting for the blankets only or plus the accessories.	Shall Quote for Blankets Only

No.	Prospective Bidder's Query	KPLC Response
5.	POLYDACRON ROPE: The diameter strength and sizes not specified in the specifications.	Shall be ½”(half inch) Diameter 2.2 kN.
6.	LOAD PICKUP TOOL: The specifications are not clear on the pickup setting. It is not specific on whether to quote for 15kV or 35kv.	Shall be 15kV or Higher.
7.	CALIBRATION EQUIPMENT: The warranty period in the ITT 15.4 States it is 24 Months, General Conditions of Contract 28 states it is 60 Months while the Specifications, Document No. KP1/13D/4/1/TSP/14/003, Clause C1,h states 18 Months	Warranty period for the calibration equipment shall be 18 Months as per the specification.
8.	On the technical Evaluation Criteria, Section III, page 33, Item 6. Submission and considering the capacity declaration form.	Shall NOT BE APPLICABLE for this tender.

All other terms and conditions remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC



JANE MUIGAI

AG. GENERAL MANAGER SUPPLY CHAIN AND LOGISTICS