



Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3514485
Stima Plaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/05/21-22/PM/ama

14th July 2022

TO:

ALL PROSPECTIVE BIDDERS

RE: ADDENDUM NO. II TO THE TENDER NO. KP1/9A.3/OT/05/21-22 FOR SUPPLY OF TOOLS AND EQUIPMENT FOR NETWORK MANAGEMENT

Please refer to the above tender.

We make the following amendment to the above Principal Tender Document (*Hereinafter abbreviated as the PTD*) for the supply of Tools and Equipment for Network Management.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

The following responses are made to clarification sought on issue in the Specifications/tender document and shall be deemed to form the addendum;

No	Query	RESPONSE
1.	Q1. We have noticed that the Specification Document for item no. 15 (PULL LIFT 1.5 Ton) has not yet been uploaded on the portal.	Attached: KP1/3CB/TSP/09/061-2 Specification for pulling and lifting machines
2.	Q2. Tension Ratchet Kindly give us the specification for this item. The specification indicated does not include this item.	Attached: KP1/3CB/TSP/09/061-3 Specification for pulling and lifting machines
3.	Q3. 3. Earthing Harness 3.1. Is it the same as portable earthing equipment?	3. Earthing Harness 3.1 YES, Earthing harness is same as portal Earthing equipment.

	<p>3.2. Clause 1.2 of the specification has two options of the earthing equipment: with copper leads and aluminium leads. The note in the succeeding sentence states that the type to be supplied shall be specified in the tender. Kindly specify to help in giving the required type.</p> <p>3.3. In addition, what should be the length of the copper or aluminium leads to reach the highest phase conductor in a vertical arrangement of 66kV lines?</p>	<p>3.2 The required type is Aluminium</p> <p>3.3 the length is Phase Leads 6m, Earth Lead 12m</p>
4.	<p>Q4. Safety Belt In the specification for safety belts, there are two types: a) Waist belt b) Work positioning lanyard</p>	<p>The safety belt shall have the two parts; a) Waist belt b) Work positioning lanyard</p>
5	<p>Q5. Manufacturer's Capacity Declaration: on the Monthly Production capacity, you have asked for a minimum of 10,000pcs per month. Is this mandatory requirement for all the items?</p>	<p>Section III - Evaluation and Qualification Criteria. CAPACITY DECLARATION FORM-Form 3.1 Manufacturer's Capacity Declaration Form – No. 1 Monthly Production Capacity</p> <p>(Manufacturer to State Monthly Production Capacity per item/tool and/or attach a separate form showing monthly production per item)</p>
6.	<p>Q6. Manufacturer's Warranty You have asked for a warranty but the form is not attached. Will any format be accepted?</p>	<p>Attached; Manufacturer's Warranty Form,</p> <p>Bidders are required to use the attached format and any format shall not be accepted.</p>
7.	<p>Q7. Please specify which type of fibre sling is needed in the Specifications. Is it the endless flexible round sling or the flat wooven endless webbing sling.</p>	<p>The type of fibre sling needed is endless flexible round sling</p>

3. CHANGE OF TENDER CLOSING DATE

The tender closing date has been extended from **14th July, 2022 to Thursday, 28th July 2022** at **10.00am**.

All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC


PETER MUCHORI
AG. SUPPLY CHAIN MANAGER, PROCUREMENT.

