



Central Office – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000  
Fax No. 254-02-3514485  
Stima Plaza, Kolobai Road  
Nairobi, Kenya

**Our Ref:** KP1/9A.3/OT/014/22-23 /PM/ri

6<sup>th</sup> March 2023

TO: ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM NO. IV TENDER FOR KP1/9A.3/OT/014/22-23 FOR SUPPLY OF RUBBER GOODS FOR LIVE LINE TEAMS**

Please refer to the above tender.

We make the following amendments to the above Principal Tender Document (*hereinafter abbreviated as the PTD*) for the Supply and delivery of Supply of Rubber Goods for Live Line Teams.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

**2. SECTION V – SCHEDULE OF REQUIREMENTS: TECHNICAL SPECIFICATIONS FOR FACE SHIELD**

The faces shield shall comply with the following Technical Specifications:

- Shall comply with ANSI Z87.1-2020, ANSI Z358.1 and ASTM F2178
- Face shield shall be non-disposable full shield, made of clear flexible material designed to come out of gasket for cleaning.
- For use in electrical environment to provide protection against electrical shock, Arc flash (12cal/cm<sup>2</sup> rating) and protection against ejection of molten metal
- Shall have a provision to allow for mounting on a safety helmet.
- Shall provide unrestricted vision and movement.
- Shall allow unrestricted functioning of any other required PPE.

All other terms and conditions remain the same.

Yours faithfully,

**FOR: THE KENYA POWER & LIGHTING COMPANY PLC**

**DR. JOHN NGENO**  
**GENERAL MANAGER SUPPLY CHAIN & LOGISTICS**

