



---

The Kenya Power & Lighting Co. Ltd.  
Central Office – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000  
Fax No. 254-02-3201889  
Stima Plaza, Kolobot Road

Our Ref: KP1/9A.2/OT/079/NM/23-24/JM/at

25<sup>th</sup> March, 2024

M/s .....

Dear Sir/Madam,

**ADDENDUM NO. 1 TENDER FOR UPRATING OF DANDORA -JUJA 132KV  
INTERCONNECTOR UNDER TENDER NO. KP1/9A.2/OT/079/NM/23-24**

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

**2. CLARIFICATIONS**

Bidders are hereby notified that the following clarifications have been made:-

NO.	BIDDERS QUERY	KPLC RESPONSE
1	Please share with us the Insulator data sheet or specifications for required insulator	Attached as appendix I
2	Are Arching horns required	YES
3	Is FAT required for the conductor accessories	NO
4	Is local Training required for accessories, if so, how many days ?	NO
5	Are low duty tension string required for the substation gantries	Use same specification referred in No.1

(i) Bidders are notified that in the specification clause 4.3, Table 1 Ratings, the Specified Mechanical Load Tension is 120kN and not 70kN as indicated.

(ii) Bidders are notified the Manufacturer and Warranty forms are attached as appendix II & III respectively.

### **3. TENDER CLOSING DATE**

The tender closing date has been extended to close on **Tuesday 9<sup>th</sup> April, 2024** at 10.00am. Tenders will be opened immediately thereafter and bidders are encouraged to witness the tender opening.

Yours faithfully,

For: **THE KENYA POWER & LIGHTING CO. PLC**



**DR. JOHN NGENO, OGW**  
**GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS**