



## Kenya Power

The Kenya Power & Lighting Co. Ltd.  
Central Office – P.O. Box 30099, Nairobi, Kenya  
Telephone – 254-02-3201000  
Fax No. 254-02-3201889  
Stima Plaza, Kolobot Road

Our Ref: **KP1/9A.2/OT/053/ADMIN/23-24/JM/at**

**27<sup>th</sup> February, 2024**

**M/s** .....

Dear Sir/Madam,

**ADDENDUM NO. 1 TO THE TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF RISER BOARD AND LOW VOLTAGE DISTRIBUTION BOARD AT NAIROBI, NAKURU AND KISUMU UNDER TENDER NO. KP1/9A.2/OT/053/ADMIN/23-24**

The following clarifications are made to the specified provisions of the Tender document.

**1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT**

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect.

The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

**2. EVALUATION CRITERIA**

Bidders are notified that clause 3.1.11 on the preliminary evaluation criteria has been amended to read as follows:-

Clause	Description
3.1.11	Duly filled Form EXP 4.1 and names with full contact as well as physical addresses of previous customers of with relevant electrical works carried out within the last Ten (10) years with reference letters from at least Three (3) previous customers.

**3. FORM OF TENDER**

Bidders are notified that amended form of tender is attached as **appendix I**.

**4. CLARIFICATIONS ON SPECIFICATION**

Bidders are notified that Guarantee Specifications Serial No. 2 to read as follows:

1	1000 A TPN ACB	Be adjustable with over current settings and having a short-circuit breaking capacity of 50KA at 415Vac, 50Hz, with shunt trip coil for fireman's switch. The ACB to be adjustable in 600-1000A range, set at 1000A. The ACBs to be motorized with both electrical and mechanical inter-lock with the Tie breaker/Coupler, with an automatic control system. Allow for manual override and remote monitored, Modbus TCP/IP, Ethernet enabled.		
---	-------------------	---	--	--

### 5. DRAWING

A revised drawing has been attached for clarity as **appendix II**.

### 6. TENDER CLOSING DATE

The tender closing date has been extended to close on **Wednesday 6<sup>th</sup> March, 2024** at **10.00am**

Yours faithfully,

For: **THE KENYA POWER & LIGHTING CO. PLC**



**DR. JOHN NGENO, OGW**  
**GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS**