

Central Office - P.O. Box 30099 - 00100 Telephone - 254 - 02 - 3201000 Stima Plaza, Kolobot Road Nairobi, Kenya www.kenyapower.co.ke

Our Ref: KP1/9A.3/OT/52/20-21/JM/bkk

28th July, 2021

TO ALL TENDERERS

RE: ADDENDUM NO. 2 TO TENDER NO. KP1/9A.3/OT/52/20-21 FOR SUPPLY OF MODULAR WIRED PROTECTION & CONTROL PANELS

Please refer to the above Tender. We make the following clarifications and amendments to the Principal Tender Document (hereinafter abbreviated as the PTD) for Supply of Modular Wired Protection & Control Panels.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT (PTD)

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATION ON QUERIES ASKED BY BIDDERS

No	Bidder's Query/ Observations	KPLC Remarks/ Clarification
1.	According to the 4.4.1 of KP1/6C/4/1/TSP/11/118, We noticed that it may not be possible to accommodate all the relays, MFM, Energy Meter, BCU, Mimic, Annunciator and accessories in one panel. Kindly clarify if it is acceptable to accommodate in two panels, one is protection panel and one is control panel.	
2.	Kindly clarify training and FAT is in the scope or not	FAT shall be carried out as stated in Appendix A.3 and C.2 (e) of the tender specification
3.	If the training is in the scope, kindly clarify if the training is going to be done at the manufacturing factory or in KPLC training school, also kindly provide the duration and number of engineers for the training.	The training shall be virtual and the video recordings submitted to KPLC
4.	We presume that the air ticket, allowance and accommodation for the KPLC engineers for the training and FAT is under KPLC scope	KPLC scope
5.	In the tender document 3.17.1 it mentioned that the warranty will remain valid for twelve (12) months from the date of	The Warranty is 60 months as per clause 7 of tender specifications No.KP1/6C/4/1/TSP/11/118.

No	Bidder's Query/ Observations	KPLC Remarks/ Clarification
	delivery to KPLC stores while in B2 and B3 of KP1/6C/4/1/TSP/13/001 it mentioned 48 months and 36months and in 7 and C1 of KP1/6C/4/1/TSP/11/118, it mentioned a warranty of 60 months from date of delivery shall be offered. Kindly clarify which one is applicable for the tender	
6.	Kindly clarify the voltage of transformer, because we noticed that under the specification of the transformers Protection and control panel for 7.5MVA,23MVA and45MVA transformers in 4.4.1 of KP1/6C/4/1/TSP/11/118 it only mentioned 33/11kV and 66/11kV and it is different requirement for transmission range transformer protection panel.	Transformation Voltage is as stated in clause 4.4.1 of KP1/6C/4/1/TSP/11/118 as 33/11kV and 66/11kV. No transmission range transformers are required.
7.	Is it acceptable to combine some protection function in one relay for instance 64Nand 51G?	Acceptable
8.	It mentioned KP1/6C/4/1/TSP/14/020 IN 4.3.7 of KP1/6C/4/1/TSP/11/118 ,Kindly provide the same	Energy meters are not required and therefore bidders are advised to ignore.
9.	Pre bid meeting –As per tender there was a pre bid on 8 th July, request to kindly confirm if it is mandatory to participate in this tender.	Not mandatory. Minutes of pre- bid Meetings to upload.
10.	Tender specification –KP1/6C/1/TSP/13/001 the said specification has been provided in the tender in 2 versions which has some differences, please confirm which one has to be followed in this tender.	The latest version dated 2020/09/04

3. DEADLINE FOR SUBMISSION OF TENDER

The tender closing date has been extended to **06th August 2021 at 10.00am.**All other terms and conditions remain as per the Principal Tender Document (PTD).

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

Ollica

RUTH OYILE

AG. SUPPLY CHAIN MANAGER, PROCUREMENT.