



The Kenya Power & Lighting Co. PLC.
Central Office – P.O. Box 30099, Nairobi,
Telephone – 254-02-3201000
Telegrams 'ELECTRIC' - www.kenyapower.co.ke
Stima Plaza, Kolobot Road

Our Ref: KP1/6A.1/OT/5/23/B18

25th January, 2024

TO: ALL PROSPECTIVE BIDDERS

Dear Sir/ Madam

CLARIFICATION NO.2 FOR TENDER NO: KP1/6A.1/OT/5/23/B18- PROCUREMENT OF DESIGN, SUPPLY, INSTALLATION AND COMMISSIONING OF PRIMARY DISTRIBUTION SUBSTATIONS AND ASSOCIATED LINES AT MBITINI SUBSTATION IN KITUI COUNTY AND MSAMBWENI SUBSTATION IN KWALE COUNTY DATED 21ST NOVEMBER, 2023.

CLARIFICATION TO BID DOCUMENT

The following responses are made to clarifications sought on various issues in the bidding document for procurement of Design, Supply, Installation and Commissioning of primary distribution substations and associated lines at Mbitini Substation in Kitui County and Msambweni Substation in Kwale County.

No.	Item	Bidder Query/Comment	KPLC Response
1.		Being an EPC contract, schedule 1 materials from abroad plays major part in the contract value. Without foreign currency given, we need to have price adjustment weightage for the contract to be part of the bid. Bidders should be able to submit for LME on materials and Exchange rate pegged 30days from date of tender submission date.	This shall be as per the issued Tender document
2.	Price schedules	Inclusion of 48VDC system in the price schedules	This shall be as per issued clarification No.1, Item No.2 and Addendum No.3 Price schedules
3.	Base radio station	Provision of technical specifications for radio telecom system	Refer to clauses 4.5.4, subclauses 7 and 8 and chapter 9.0- Volume II of the Tender document
4.	Transformer protection	GTPs for a differential relay	This shall be as per issued clarification No.1, Item No.2 and Addendum No.3 Price schedules
5.	Marshalling Kiosks	Provision of technical specifications for Bay Marshalling Kiosks	Refer to Volume II of tender document subclause: 4.8.1, 8.7.6 and 8.7.7

No.	Item	Bidder Query/Comment	KPLC Response
6.	LV cables	Provision of technical specifications for LV cables- 2.5mm2 is not enough for all i.e. power, signal, command and measurements.	Refer to Volume II of tender document subclause: Paragraph 2.8, 5.23 and subclause 8.13.4

Yours faithfully,

For: KENYA POWER & LIGHTING COMPANY PLC.



Dr. JOHN NGENO, OGW

GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS