

**DOCUMENT NO.: KP1/13D/4/1/TSP/14/11-04**



**Kenya Power**

**THREE-PHASE WATT-HOUR SMART METER WITH SELECTABLE PREPAYMENT  
AND POSTPAID MODES- SPECIFICATION**

A Document of The Kenya Power & Lighting Company PLC

May 2021



**THREE-PHASE WATT-HOUR  
SMART METER WITH  
SELECTABLE PREPAYMENT  
AND POSTPAID MODES  
- SPECIFICATION**

Doc. No.	KP1/13D/4/1/TSP/14/011-5
Issue No.	1
Revision No.	0
Date of Issue	2021-05-18
Page iv	

**0.1 CIRCULATION LIST**



COPY NO.	COPY HOLDER
1	Manager, Standards
2	Electronic copy (pdf) on Kenya Power server ( <a href="http://172.16.1.40/dms/browse.php?fFolderId=23">http://172.16.1.40/dms/browse.php?fFolderId=23</a> )


**REVISION OF KPLC STANDARDS**

To keep abreast of progress in the industry, KPLC Standards shall be regularly reviewed. Suggestions for improvements to approved Standards, addressed to the Manager, Standards Department are welcome.



**©THE KENYA POWER & LIGHTING COMPANY PLC**

Users are reminded that by virtue of Section 25 of the Copyright Act, 2001(Revised 2009) Cap 130 of the Laws of Kenya, copyright subsists in all KPLC Standards and except as provided under Section 26 of this Act, no KPLC Standard produced by KPLC may be reproduced, stored in retrieval system by any means without prior permission from the Managing Director & CEO, KPLC.

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed: 	Signed: 
Date: 2021-05-18	Date: 2021-05-18

 Kenya Power	<b>THREE-PHASE WATT-HOUR SMART METER WITH SELECTABLE PREPAYMENT AND POSTPAID MODES - SPECIFICATION</b>	Doc. No.	KP1/13D/4/1/TSP/14/011-5
		Issue No.	1
		Revision No.	0
		Date of Issue	2021-05-18
		Page iv	


0.2 AMENDMENT RECORD				
Rev No.	Date (YYYY-MM-DD)	Description of Change	Prepared by (Name & Signature)	Approved by (Name & Signature)
0	2021-05-18	New Issue	Eng. S. Nguli Eng. J. Ndirangu	Dr. Eng. Peter Kimemia

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed: 	Signed: 
Date: 2021-05-18	Date: 2021-05-18

## Table of Contents


0.1 Circulation List .....	2
0.2 Amendment Record .....	3
FOREWORD .....	5
1. SCOPE .....	0
2. NORMATIVE REFERENCES .....	0
3. DEFINITIONS AND ABBREVIATIONS .....	2
4. REQUIREMENTS .....	4
4.1 Operating Conditions .....	4
4.2 Design and construction requirements .....	5
4.3 Electrical Requirements .....	13
4.4 Interoperability Requirements .....	18
4.5 Quality Management System .....	19
5 TESTS AND INSPECTIONS .....	19
6 MARKING AND PACKING .....	22
7 DOCUMENTATION .....	23
8 INFORMATION AND WARRANTY (IN CASE OF TENDER AWARD) .....	25
ANNEX A (Normative):Guaranteed Technical Particulars .....	27

Issued by: Head of Section, Standards Development


Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18

 Kenya Power	<b>THREE-PHASE WATT-HOUR SMART METER WITH SELECTABLE PREPAYMENT AND POSTPAID MODES - SPECIFICATION</b>	<b>Doc. No.</b>	KP1/13D/4/1/TSP/14/011-5
		<b>Issue No.</b>	1
		<b>Revision No.</b>	0
		<b>Date of Issue</b>	2021-05-18
		<b>Page iv</b>	

## FOREWORD

This Specification has been prepared by the Commercial Service and Sales in collaboration with Standards Department, Meter Central Laboratory, ICT, Network Management all of The Kenya Power & Lighting Company PLC (KPLC). It lays down requirements for Three-Phase Watt-hour Smart Meter for use in the KPLC Advanced Metering Infrastructure (AMI).

The Specification establishes uniform requirements for Three-Phase Watt-hour Smart Meters

Specifications in this series are:



- (i) TSP/14/011-02 - Single-Phase Split Din-rail Mounting Static Watt-hour Prepayment Meter for Active Energy- Using Power Line Carrier (PLC) as Medium of Communication Between Measurement and Control Unit (MCU) and User Interface Unit (UIU)
- (ii) TSP/14/011- 03 - Single-Phase Post-Payment Watt-hour Meter for Active Energy
- (iii) TSP/14/011 – 05 - Single-Phase Watt-Hour Smart Meter with Selectable Prepayment and Postpaid Modes- Specification

The Specification is intended for use by KPLC for procurement of Three-Phase Watt-hour Smart Meter and does not purport to include provisions of a contract.

Users of this KPLC specification are responsible for its correct interpretation and application.

The following are members of the team that developed this specification:

<b>Name</b>	<b>Division</b>
Dr. Eng. Peter Kimemia	IESR
Eng. Benjamin Muoki	ICT
Peter Wanyonyi	Commercial Service and Sales
Maina Gatheru	Commercial Service and sales
Cleophas Ogutu	Infrastructure development
Eng. Raphael Ndolo	Network Management
Eng. Stephen Nguli	IESR
John Kenyanya	IESR

<b>Issued by: Head of Section, Standards Development</b>	<b>Authorized by: Head of Department, Standards</b>
Signed: 	Signed: 
Date: 2021-05-18	Date: 2021-05-18

## 1. SCOPE

- 1.1.1 This specification is for newly manufactured Three-Phase Watt-hour Smart Meter for measurement of alternating current active energy in 3 x 230/415 V, 50 Hz networks.
- 1.1.2 The Meters are for use in KPLC's Advanced Metering Infrastructure (AMI) system. The Meter shall communicate via GSM/GPRS/3G/4G/NB-IoT and shall also support field/hot swappable/replaceable plug-in type bi-directional communication modules with easy adaptability to network interfaces with other modes of communications; G3 PLC, Radio Frequency, Wi-Fi, Fibre Optic, RS485, Modbus, IP port, Broadband PLC (BPL), Narrow band PLC (PLC), RF receiver for Long-Range WiFi (LoRa), etc.
- 1.1.3 The modem shall support meter communication protocols as per DLMS/COSEM standards
- 1.1.4 The specification also describes the inspections and tests to be carried out on the meters as well as Schedule of Guaranteed Technical Particulars to be filled and signed by the manufacturer and submitted with bids for tender evaluation.
- 1.1.5 The specification stipulates the minimum requirements for Three-Phase Watt-hour Smart Meter acceptable for use in KPLC's system and it shall be the responsibility of manufacturer to ensure adequacy of the design, good workmanship, good engineering practice and adherence to the Specifications and applicable Standards and regulations in the manufacture of the Meters.


## 2. NORMATIVE REFERENCES

The following Standards contain provisions, which through reference in text constitute provisions of this Specification. Unless otherwise stated, the latest Editions (including amendments) apply. In case of conflict, the requirements of this Specification take precedence.

IEC 61968-9:2013	Application integration at electric utilities - System interfaces for distribution management - Part 9: Interfaces for meter reading and control
IEC 60695-2-11:2014	Fire Hazards Testing-Part 2-Test Methods-Section 1/sheet: Glow-wire end-product test and guidance.
IEC 61000-4-5:2014	Electromagnetic Compatibility (EMC)-Part 4-5: Testing and measurement Techniques- Surge immunity test
IEC 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use -Part 1: General requirements
IEC 61140:2016	Protection against electric shock-common aspects for installation and equipment
IEC 62056-6-2:2017	Electricity metering data exchange - The DLMS/COSEM suite - Part 6-2: COSEM interface classes.

IEC 62058-11:2008	Electricity Metering Equipment (AC) -Acceptance Inspection Part 11- General Acceptance Inspection methods
IEC 62058-31:2008	Electricity Metering Equipment (AC) -Acceptance Inspection Part 31- Particular requirements for static meters for active energy (classes 0.2S, 0.5S, 1 & 2)
IEC 61557-1: 2019	Electrical safety in low voltage distribution systems up to 1000V A.C. and 1,500V D.C. – Equipment for Testing, measuring or monitoring of protective Measures-Part 1: General Requirements
IEC 61810-1:2015	Electromechanical elementary relays - Part 1: General and safety requirements
IEC 60529:2013	Degrees of protection provided by Enclosures (IP Code)
IEC 62052-11:2003	Electricity Metering equipment (A.C) – General Requirements, Tests and Test Conditions- Part 11: Metering equipment.
IEC 62053-21:2020	Electricity metering equipment - Particular requirements - Part 21: Static meters for AC active energy (classes 0,5, 1 and 2)
IEC 62055-31:2005	Electricity metering – Payment systems – Part 31: Particular requirements – Static payment meters for active energy (classes 1 and 2).
IEC 62055-41:2018	Electricity metering - Payment systems - Part 41: Standard transfer specification (STS) - Application layer protocol for one-way token carrier systems
IEC 62055-51:2007	Electricity metering - Payment systems - Part 51: Standard transfer specification (STS) - Physical layer protocol for one-way numeric and magnetic card token carriers
IEC 62056-21	Electricity metering - Data exchange for meter reading, tariff and load control - Part 21: Direct local data exchange
IEEE 1901.2-2013	IEEE Standard for Low-Frequency (less than 500 kHz) Narrowband Power Line Communications for Smart Grid Applications.
SANS1524-1:2014	Electricity prepayment Systems, Part 1: Prepayment meters.

**Issued by: Head of Section, Standards Development**

**Signed:** 

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:** 

**Date: 2021-05-18**

ISO 75-1:2020

Determination of temperature of deflection under load — Part 1: General test method.

ISO 9001:2015

Quality management systems — Requirements

### 3. DEFINITIONS AND ABBREVIATIONS

For the purposes of this Specification, the Terms, Definitions and Abbreviations given in the Reference Standards apply, and shall include the following:

DLMS/COSEM	Device Language Message Specification/Companion Specification for Energy Metering
CIU:	Customer Interface Unit
EDIS:	Energy Data Identification System
EMC:	Electromagnetic Compatibility
GPRS:	General Packets Radio Service
GSM:	Global System for Mobile communications
$I_b$ :	Basic current of an electric meter
$I_{max}$ :	Maximum current of an electricity meter
$I_n$ :	Nominal current of a transformer coupled electricity meter
IEC:	International Electro-Technical Commission.
ISO:	International Organization for Standardization
LCD:	Liquid Crystal Display
KPLC:	Kenya Power and Lighting Company PLC
RF:	Radio Frequency
TCP/IP:	Transmission Control Protocol/Internet Protocol


Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:



Signed:



Date: 2021-05-18

Date: 2021-05-18

TMR:	Energy Tele-Meter Reading system
Hz	Hertz
kV	Kilovolt
KWH	Kilowatt-hour
LED	Light emitting diode
MCU	Measurement and Control Unit
PLC	Power Line Carrier
SRE	Significant Reverse Energy
STS	Standard Transfer Specification
UIU	User Interface Unit
BPL,	Broadband PLC
LoRa,	Long-Range WiFi
Nb-IOT	Narrowband Internet of Things
G3 PLC	Narrow band PLC based on ITU G.9903
Prime PLC	PowerLine Intelligent Metering Evolution PLC
SMS	Short Message Service
USSD	Unstructured Supplementary Service Data
CSD	Circuit Switched Data

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-05-18

Date: 2021-05-18



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 4 of 51</b>	

#### **4. REQUIREMENTS**

##### **4.1 OPERATING CONDITIONS**

###### **4.1.1 Operating Environmental Conditions**

The meters shall be suitable for continuous outdoor operation in tropical climate with the following conditions:

- a) Altitude of up to 2400m above sea level
- b) Humidity of up to 95%,
- c) Average ambient temperature of +30°C with a minimum of -1°C and a maximum of +50°C and;
- d) Pollution: Design pollution level to be taken as “Heavy” (Pollution level III) for inland and “Very Heavy” (Pollution level IV) for coastal applications:
- e) Isokeraunic levels of up to 180 thunderstorm days per year.

###### **4.1.2 System Characteristics**

4.1.2.1. The meter shall be connected to an overhead or underground-earthed system.

4.1.2.2 The nominal voltage ( $U_n$ ) is 3 x 230/415 volts, 50Hz.

**Issued by: Head of Section, Standards Development**


**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**

 <b>Kenya Power</b>	<b>THREE-PHASE WATT-HOUR SMART METER WITH SELECTABLE PREPAYMENT AND POSTPAID MODES - SPECIFICATION</b>	<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
		<b>Issue No.</b>	<b>1</b>
		<b>Revision No.</b>	<b>0</b>
		<b>Date of Issue</b>	<b>2021-05-18</b>
		<b>Page 5 of 51</b>	

## 4.2 DESIGN AND CONSTRUCTION REQUIREMENTS

### 4.2.1 General Requirements

- 4.2.1.1 The meter shall be constructed as Three-phase Four-wire Direct-Connected Prepaid/Postpaid meters. The meter shall support both prepaid and postpaid modes.
- 4.2.1.2 The meter shall be of British Standard (BS) 5685-foot print for standardized mounting for asymmetrical (BS) wiring
- 4.2.1.3 The meter shall have terminals with bottom entry for cables and the arrangement shall be L1L1: L2L2: L3L3: NN for 3 phase 4-wire meters
- 4.2.1.4 The meter base and cover shall be of non-metallic, non-hygroscopic, flame retardant, polished material having high impact-resilience and low dirt absorption properties.
- 4.2.1.5 The meter front cover shall be of translucent material but shall have a window (clear glass or polycarbonate) for reading the display and for observation and the terminal cover shall be transparent with sealable Nickel-plated steel screws.
- 4.2.1.6 The meter shall conform to the degree of protection of at least IP 54 as given in IEC 60529:2013. The terminals shall be designed to ensure protection from ingress of water and dust.
- 4.2.1.7 The meter shall have a real-time clock controlled by a quartz crystal oscillator. It shall be possible to reset the clock without loss of billing data that shall be synchronized with the AMI system.
- 4.2.1.8 The material of which the terminal block shall be capable of passing the tests given in ISO 75-1:2020.
- 4.2.1.9 The meter shall be for front projection mounting.
- 4.2.1.10 The meter shall have an internal back –up battery to support the LCD display, clock and calendar in the event of an AC power failure. The life expectancy of the battery shall last for a minimum of 10 years.
- 4.2.1.11 The meters shall be equipped with lockable/sealable push buttons where such buttons are used to program the meter parameters.
- 4.2.1.12 The potential link of the meters shall be internal (inside the sealed part of the meter).
- 4.2.1.13 The meter shall have a sealing provision for terminal cover. The meter terminal cover shall be of the long type with cable entry knock-offs which shall be at least 20mm from the terminal block.

**Issued by: Head of Section, Standards Development**

**Authorized by: Head of Department, Standards**

**Signed:**

**Signed:**

**Date: 2021-05-18**

**Date: 2021-05-18**



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 6 of 51</b>	

- 4.2.1.14 The meter shall have terminal cover open detection. Once the terminal cover is opened, the load shall be disconnected.
- 4.2.1.15 The meters' terminal holes and screws shall be of moving-cage type made of brass or nickel-plated brass for high strength and good conductivity. The copper content in the brass shall be at least 60%.
- 4.2.1.16 The meter shall support double element circuit measurement (phase and neutral circuits).
- 4.2.1.17 The meter body dimensions shall not exceed: Height = 290mm; Width = 170mm; and Depth = 90 mm;
- 4.2.1.18 The MCU shall have a keypad on the body of the meter for keying in the tokens and shall be IP54 compliant.
- 4.2.1.19 The MCU body shall be ultrasonically sealed for life and there shall be no screws on the MCU body except for the termination of cables.
- 4.2.1.20 The meter shall have terminal cover open detection mechanism. Once the terminal cover is opened, the load shall be disconnected. The mechanism shall be designed to operate as in sub-clauses (a) to (c) below:
- The MCU shall be supplied with loading switch in open mode and installer can open terminal cover when MCU is not activated by commissioning code (token).
  - After installation of MCU, the installer will input a commission code (token) to close the loading switch and activate terminal cover open detection function. The commissioning code/token shall precede any token to be keyed into the meter to activate all functionalities of the meter. The meter shall reject any token (clear tamper token, credit token, etc.) input into the meter as long as the commissioning token has not been keyed into the meter.
  - After commissioning token is put into the MCU and loading switch closes, opening of the terminal cover shall lead to tamper. When MCU has power and terminal cover is opened, MCU will disconnect immediately. When MCU has no power and terminal cover is opened, MCU will detect and record the event and disconnect immediately power resumes.

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**




**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

Doc. No.	KP1/13D/4/1/TSP/14/011-4
Issue No.	1
Revision No.	0
Date of Issue	2021-05-18
Page 7 of 51	


- 4.2.1.21 The MCU shall be sealed and its Printed Circuit Boards conformal coated in a manner so as not to allow malfunction due to ingress of moisture, vermin, dust, chemicals and temperature extremes.
- 4.2.1.22 The terminals shall be of suitable rating to carry continuously I<sub>max</sub> current.
- 4.2.1.23 Terminal holes shall be of at least 10-mm diameter and 15mm in depth.
- 4.2.1.24 The meter terminal cover shall have screw inserts sealable with utility wire seals.
- 4.2.1.25 The meter protection class shall be Class II (Double insulated) as per IEC 61140:2016 standard.
- 4.2.1.26 The meter shall have a non-volatile memory capable of data storage and with long-term data retention period of not less than 10 years or for the certified life of the meter or whichever is greater without an electrical supply being supplied to the meter.
- 4.2.1.27 The meter shall have register codes as per the list of the OBIS codes provided.
- 4.2.1.28 The principal unit for the measured values shall be the kilowatt-hour (kWh) for active power and kilo volt-ampere for reactive power (kVAR) with a resolution of at least 0.01 for testing purposes.
- 4.2.1.29 The cumulative consumption register of the meter shall **NOT** be resettable to zero.
- 4.2.1.30 The meter shall detect significant reverse energy (SRE) when the line and load wires are swapped and this shall be indicated on the LCD display of the meter.
- 4.2.1.31 The meters shall continue to operate correctly and decrement credit during SRE detection for prepaid meters and increment for postpaid meters.
- 4.2.1.32 The meters shall have LED indicators for testing and indication of Active power and Reactive power consumption.
- 4.2.1.33 The spacing between the LEDs shall be sufficient so as not to disrupt the testing of the meter during the verification of the accuracy of the energy meter.
- 4.2.1.34 The internal circuit of the meter shall be designed in a manner to delink the optical interface and the display to allow interrogation of the meter through the optical interface when the LCD display is not working.
- 4.2.1.35 The MCU enclosure material shall be of good dielectric and mechanical strength with minimum thickness of 2.0mm. The material shall comply with IEC 60695-2-11 glow wire test.

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 8 of 51</b>	

4.2.1.36 The bidders shall specify Original Equipment Manufacturers (OEM) and any Technical Partners in the design of their meters.

#### **4.2.2 Communication**

4.2.2.1 The meter shall support bi-directional communication.

4.2.2.2 The meters shall be compliant with the DLMS/COSEM communication protocol. The bidder shall submit the Compliance Certificate together with the tender document for evaluation.

4.2.2.3 The meter shall have an integrated GPS module on the meter PCB for locating the meter.

4.2.2.4 The meter shall be equipped with an infrared optical port compliant with the IEC 62056-21 standard for meter programming and data downloading.

4.2.2.5 The MCU shall come fitted with an SCSSCAAA9 (MC171) compliant data port for programming and interrogating the meter.

4.2.2.6 The Meters shall have a modular design and have a GPRS communication module and also support other communication modules and the point at which it is placed shall be sealable. The Meter shall be able to communicate with a remote central system using a plug in modem/module, through the GPRS 3G networks and higher.

4.2.2.7 The communication module shall be hot swappable.

4.2.2.8 The communication module shall be interchangeable by the different interfaces as described in clause 4.2.2.9

4.2.2.9 The Meter shall communicate via GSM/GPRS/3G/4G/NB-IoT but shall also have a sealable slot to support field/hot swappable/ replaceable plug-in type bi-directional communication modules with easy adaptability to network interfaces with other modes of communications: G3 PLC, Radio Frequency, Wi-Fi, Fibre Optic, RS485, Modbus, IP port, Broadband PLC (BPL), Narrow band PLC (PLC), RF receiver for Long-Range WiFi (LoRa), etc. All the interfaces shall be DLMS/COSEM compliant.

4.2.2.10 The Meters shall have RS485 communication interface that include at least a 4 digital outputs, isolated from all other meter circuits with fail-safe circuitry able to withstand AC 230V for 2 minutes without damage.

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**

- 4.2.2.11 Meter's firmware shall be upgradable remotely and locally. Upgrading of firmware shall not stop or affect meter's metrology.
- 4.2.2.12 (a) The communication module shall support both SMS and GPRS modem and support the mode of: on line and on-demand on line.
- (b) The communication module shall not be powered directly from the terminals and shall have a backup battery to allow remote communication in the event of power outage.
- 4.2.2.13 The communication module shall support USSD, CSD communication.
- 4.2.2.14 Meter shall send a 'last gasp' power outage response when it loses power and a 'First Breath' restoration message when power is restored.
- 4.2.2.15 The meter shall support manual meter reading in case of loss of communication to the meter.
- 4.2.2.16 The meter shall work under Postpaid Mode or Prepaid Mode. The switch of mode shall be done via meter specific token or optical communication or via the system.
- 4.2.2.17 The meters shall be supplied together with a scanner and laptop for scanning the meters at KPLC warehouse and a laptop loaded with software for interrogating the meter data and loading commissioning and credit token during testing at our laboratory. The laptop specification shall be as in Table 1.

**Table 1: Laptop Technical Specifications**

Description	Mandatory Minimum Requirements
Processor	Intel Core i7-5500 (2.60GHz 1600MHz 3MB, 8 Cores)
RAM	16GB DDR4-2133MHz SODIMM
Operating System	Windows 10 pro 64 bit
Optical Drive	Super Multi DVD-RW or DVD Recordable Burner
Hard Disk	1TB 7200 rpm Hard Drive
Display Panel	15.6" FHD LED Glossy (1920x1080) with integrated Webcam 720p camera
Graphics	Integrated Intel HD Graphics 520
Internal Audio	Integrated HD audio internal speaker (standard) or Stereo with Dolby Audio TM, 1xMic Headphones Combo
Communications	GPRS/ HSDPA Modem, Integrated Intel Gigabit Network Connection (10/100/1000 NIC)
Wireless	Intel 802.12 AC WLAN and Bluetooth(R)

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-05-18

Date: 2021-05-18



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 10 of 51</b>	

Interfaces	VGA, MDP, 4-in-1 Card Reader, Smart Card Reader. RJ-45, Headphone and Microphone Jack, Mechanical Docking, 2 x USB 3.0, W/WAN SIM, Express Card Slot, 1 HDMI port, Bluetooth, Wi-Fi enabled
Pointing Devices	Touchpad with scroll zone, Two Pick Buttons or Pick Stick, Two Pick Buttons
Keyboard	Keyboard with Number Pad – English (Standard)
Mouse	External USB Mouse
Warranty	1 Year
Power	4-cell 41 WHr Lithium-ion Battery; External AC adapter
Power Supply	230V AC, 50 Hz, British plugs
Carrying Case	Genuine Leather Carrying Case
Manufacturer's Authorization	Manufacturers Authorization Certificate/ Letter and for the models quoted, the principal (Manufacturer) MUST have an established regional office in Kenya.

#### 4.2.3 Meter Display

- 4.2.3.1 The meters shall have a backlight seven-segment Liquid Crystal Display (LCD) for displaying parameters and measured values.
- 4.2.3.2 The meter LCD shall have at least seven (7)-numerical characters comprising of selectable integers and two decimals points for energy measurement. The minimum character height shall be eight (8) mm.
- 4.2.3.3 The meters LCD shall be capable of displaying the current state of the relay via symbols.
- 4.2.3.4 The meters LCD shall be capable of displaying various tampering conditions of the meter.
- 4.2.3.5 The display parameters shall be configurable by software action.
- 4.2.3.6 The LCD display shall operate in at least two modes, namely, basic and extended data list display using push buttons on meter front.
- 4.2.3.7 Meters shall have provision for reading the meter at site even when mains power supply fails.

#### 4.2.4 Functionality Requirements

##### 4.2.4.1 Measurement and Control Unit (MCU)

- 4.2.4.1.1 The MCU shall measure and display the energy quantities of active power, reactive power and apparent power in both import and export modes.
- 4.2.4.1.2 The meters shall be capable of profiling multiple channels of energy, demand (KVA, KW, KVAh), voltage, current, power factor, harmonics, for a period of at least six (6) months for 60 minutes data intervals.
- 4.2.4.1.3 The meter shall be able to measure the units consumed in the event of an imbalanced load or the absence of one or two phases.
- 4.2.4.1.4 The meters shall measure Energy correctly even when the phase rotation/sequence is incorrect.

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed:

Date: 2021-05-18

- 4.2.4.1.5 The meters shall be capable of recording of active and reactive energy in all four (4) quadrants with up to four (4) tariffs.
- 4.2.4.1.6 The meter shall have at least four (4) registers for energy.
- 4.2.4.1.7 The meter shall be capable of measuring energy in security mode and also record reversed units.
- 4.2.4.1.8 The Meter shall indicate on the LCD display reverse energy consumption.
- 4.2.4.1.9 The meter shall have capability of closing end of billing period on any selected date of the month selectable by software.
- 4.2.4.1.10 The meter's billing registers shall NOT be re-settable to zero.
- 4.2.4.1.11 The meters shall have at least twelve (12) billing historical data stored in memory and retrievable by software action.
- 4.2.4.1.12 The meter shall have a load switch to disconnect the load circuit on the expiry of credit balance in the case of prepayment meters.
- 4.2.4.1.13 The load switch shall automatically restore the load circuit after token top up for prepayment meters.
- 4.2.4.1.14 The meter load switch shall comply with the requirements given in IEC 62055-31:2005.
- 4.2.4.1.15 The meters shall have a programmable power limit setting that shall disconnect the load once exceeded and reconnect once the load falls below the set limit
- 4.2.4.1.16 The meters shall disconnect the load if power failure is detected and connect the load after normalization.
- 4.2.4.1.17 The meters shall be able to indicate absence or presence of continuous power by use of a Light Emitting Diode (LED).
- 4.2.4.1.18 The MCU shall have an LED indicator to show the rate of consumption. The pulse rate shall be proportional to current rate of consumption.
- 4.2.4.1.19 The MCU shall have an LED to indicate the presence of an alarm of any registered event on the meter.
- 4.2.4.1.20 The MCU shall have a self-diagnostic feature to diagnose the status of the functions of the meter.

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**

- 4.2.4.1.21 The MCU shall have a Liquid Crystal Display (LCD) for numeric display and language independent pictograms to identify operational features. The LCD shall have a wide viewing angle of 45 deg. to 60 deg. with, up to one-meter distance.
- 4.2.4.1.22 The Live and Neutral shall be DC immune complying with requirements of IEC 62052-11:2003 and IEC 62055-31:2005.
- 4.2.4.1.23 The MCU shall come fitted with an SCSSCAAA9 (MC171) compliant data port for programming and interrogating the meter. Two (2) sets of data interrogating and programming probes and software (1 each for optical and SCSSCAAA9 ports) shall be provided with the meter sample for evaluation. For the winning bidders, each delivery of 100,000 meters shall have 50 sets of probes and read only software for use with the optical and the SCSSCAAA9 ports.
- 4.2.4.1.24 The MCU shall be supplied together with a plastic card of dimension 60mm x 40 mm (length x height) indicating the meter number. A tolerance of  $\pm 1$ mm will be acceptable. The meter serial number shall be engraved on the card together with its bar code version. No random redundant digits shall be added to the meter number.
- 4.2.4.1.25 The MCU shall be with Nil units pre-loaded (i.e. 0 (Zero) kWh for prepaid meters.

#### **4.2.5 Time-of-use tariff measurements**

- 4.2.5.1 The meters shall be capable of measuring and displaying time-of-day active and reactive energy consumption up to four tariff registers.
- 4.2.5.2 The meters shall be capable of measuring and displaying time-of-day demand (kW and kVA) consumption up to four tariff registers.
- 4.2.5.3 Each tariff register shall be set to operate over defined time periods during a 24-hour day.
- 4.2.5.4 The meters shall have at least two seasons and four day types namely weekday, Saturday, Sunday and Special/Holiday with switching times set independently.
- 4.2.5.5 The meters shall have at least forty (40) special days to take care of national holidays, world days and Easter holidays.

#### **4.2.6 Demand measurements**

- 4.2.6.1 The meters shall be capable of measuring and displaying active, reactive and apparent demand consumption in both import and export modes.
- 4.2.6.2 The meters shall display demand values and their time and date stamps.
- 4.2.6.3 The meters shall measure demand correctly even when the phase rotation/sequence is incorrect.
- 4.2.6.4 The meter shall have at least four (4) registers for demand.
- 4.2.6.5 The meters shall have a capability of closing end of billing period on any selected date of the month selectable by software.

**Issued by: Head of Section, Standards Development**


**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**

 Kenya Power	<b>THREE-PHASE WATT-HOUR SMART METER WITH SELECTABLE PREPAYMENT AND POSTPAID MODES - SPECIFICATION</b>	Doc. No.	KP1/13D/4/1/TSP/14/011-4
		Issue No.	1
		Revision No.	0
		Date of Issue	2021-05-18
		Page 13 of 51	

4.2.6.6 The meters shall have at least twelve (12) billing historical data stored in memory and retrievable by software action. The current and billing/historical data shall be available on meter display for reading and billing purposes.

#### 4.2.7 Instrumentation data measurements

4.2.7.1 The meters shall be capable of displaying instrumentation data namely instantaneous phase voltages and currents, phase angles, and power factor.

4.2.7.2 The meters shall be capable of measuring and displaying instantaneous power (active, reactive and apparent).

4.2.7.3 The meters shall be capable of measuring and displaying average power factor for the current and the previous billing months.

4.2.7.4 The meters shall be capable of continuous display of the presence or absence of individual phase voltages.

4.2.7.5 The meter shall have diagnostics to alert of any abnormal three phase power condition, such as: over/under voltage, missing voltage, missing current, improper meter vectors for service, reverse power flow, etc.

#### 4.2.8 Load profiling

4.2.8.1 The meters shall be capable of profiling multiple channels of energy, demand (kVA, kW, kVAr), voltage, current, power factor, harmonics, for a period of at least six (6) months for 60 minute intervals.

4.2.8.2 The load profile integration period shall be programmable from one (1) minute up to a maximum of sixty (60) minutes.

#### 4.2.9 Power Quality Analysis

4.2.9.1 The meter shall collect and record basic power quality information – overcurrent, total no. of alarms, power outages, voltage and current, average power factor and line frequency, etc.

4.2.9.2 The meter shall be able to provide voltage sag and swell detection.


4.2.9.3 The meters shall provide Total Harmonic Distortion (THD) event detection at least up to the 10th harmonic with analysis for unusual system conditions.

### 4.3 Security features

The meters shall be capable of event recording and communication, which shall include but not be limited to the following:


- Power ups and power downs with date and time stamp;
- Individual phase failure, with date and time stamps;
- Over- and under-voltages based on a pre-set threshold with date & time stamp;

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18

- d) Battery voltage status (if applicable);
- e) Memory status;
- f) Meter errors,
- g) Date and time of last programming/parameterization;
- h) Date and time of the last end of billing period;
- i) Firmware upgrades
- j) Prepayment events
- k) Terminal cover removal, even during a power failure
- l) Main meter cover removal, even during a power failure
- m) Communications removal
- n) Magnetic detection, at least 0.5 mT
- o) Bypassing neutral
- p) Interchanging incoming and outgoing leads

The LCD shall display events that have occurred. The events displayed shall include but not be limited to the following:

- a) Meter errors
- b) Phase failures
- c) Battery voltage status (if applicable)
- d) Alarms
- e) Warning messages
- f) Prepayment mode
- g) Terminal cover removal
- h) Communications removal
- i) Magnetic detection, at least 0.5 mT

#### 4.4 Electrical Requirements

- 4.4.1 The meter shall be operated from mains with reference values of 3 x 230/415V, 50 Hz  $\pm$  10 %, with a load switching voltage range from 0.4Un to 1.3Un phase to neutral.
- 4.4.2 The load switch shall be of bi-stable type designed and manufactured in accordance with IEC 61810- 1, as well as meet the overload and short circuit requirement of IEC 62052-11 /

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**


62055-31:2005. The load switch shall interrupt the supply when the voltage is below 0.4  $U_n$  and above 1.3  $U_n$  phase to neutral.

- 4.4.3 The load switch shall automatically restore supply within a minute when the voltage falls within 0.4  $U_n$  – 1.3  $U_n$  phase to neutral.
- 4.4.4 The meters shall be connectable for 3 Phase 4-wire systems, a permanent connection drawing of which shall be printed on the meter body. Stickers of any kind shall not be accepted.
- 4.4.5 The meter shall have Reference Standard Electrical Design Parameters as in Table 2 below.

**Table 2: Summary of Electrical Parameters**

Measurement and Control Unit	
Electrical Parameters	
Accuracy Active power	kWh Class 1 (IEC 62055-31:2005)
Accuracy Reactive power	kVAr Class 2 (IEC 62055-31:2005)
Rated Nominal Voltage ( $U_n$ ), Frequency (Hz)	3 x 230/400V, 50Hz $\pm$ 10% in line with Kenya National Distribution Grid Code, 2017
Load switching voltage range	0.4 $U_n$ to 1.3 $U_n$ (Phase to neutral)
Base Reference current, $I_b$	10A
Max. Voltage circuit burden	1W and 5 VA @ 3 x 230/415V, 50Hz, 30 <sup>0</sup> C
Max. Current circuit burden	2VA @ 5A, 50Hz, 30 <sup>0</sup> C per phase
Maximum Current $I_{max}$ (A)	120 A.
Protective class	Class II (double insulated)
Accurate metering range	0.002 $I_b$ to $I_{max}$
Starting current	0.002 $I_b$
Running with no-load	No more than one pulse on application
Short circuit current	30 $I_{max}$
Meter Constant	1000 imp/kwh
Meter Constant	1000 imp/kVAr
Disconnection Device	
Type	Single pole latching contactor, 100 A.
Mechanical life at maximum power, PF=1	At least 3,000 cycles
Maximum switching current per phase	At least 100 A
Maximum switching voltage per phase	At least 265 V AC

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 16 of 51</b>	

Maximum overload current per phase	120 A (30 min)
<b>Insulation; Over voltage and Surge Protection</b>	
Insulation classification	Protective Class II
Insulation level	At least 6 kV rms for 1 minute
Over voltage withstand	400 VAC for 48 hours
Voltage Impulse withstand	At least 6 kV, 1.2/50 $\mu$ s (IEC 62052-11) with 2 $\Omega$ source
Current Impulse withstand	impedance
Lightning Surge Withstand	At least 5kA, 8/20 $\mu$ s
	At least 30kA, 4/10 $\mu$ s
<b>Electromagnetic compatibility</b>	
Electrostatic discharge	15 kV air discharge
Immunity to HF fields	80 MHz to 2 GHz @ 10V/m with load; 80 MHz to 2 GHz @ 30V/m no load- Accuracy not affected by magnetic fields from all sides-front, sides, top and bottom of the meter.
Immunity to Fast Transient Bursts	
Radio interference	4 kV
<b>Communication Circuitry</b>	
Type	<b>GPRS</b>
Rated Impulse Voltage	Peak Voltage 6 kV (1.2/50 $\mu$ s) waveform (IEC 62052-11)
	Protective Class II
Insulation level	6 kV <sub>rms</sub> (1 Minute) - IEC 62052-11 Protective Class II
Communication Protocol	DLMS/COSEM (IEC 62056)

**Note:** The above electrical design parameters shall all form part of the Type Test Report:

The meter shall have Default Factory Parameters settings as in Table 3 below:

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**


**Table 3: Default Factory Parameters Settings**

CONFIGURATION ITEM	DATA VALUE
<b>Basic Parameters</b>	
Rated Voltage	3 x 230/415V
Basic Current (I <sub>b</sub> )	10A
Maximum Current(I <sub>max</sub> )	100A
Meter Constant for Active power	1000imp/kWh
Meter Constant for Reactive power	1000imp/kVAr
Accuracy class for active power	1
Accuracy class for reactive power	2
Frequency	50Hz
Time zone	GMT+3
<b>Measurement configuration</b>	
Active	$ A_i  =   +A   +   -A  $
	$ A_e  =   -A  $
Reactive	$ R_i  =   +R   +   -R  $
	$ R_e  =   -R  $
<b>Prepaid parameters</b>	
Factory default payment mode	Prepaid/Postpaid
Pre-load credit	0KWh
Low credit warning(Alarm green LED-Permanent)	$\leq 20KWh$
Low credit warning(Alarm Red LED-Permanent)	$\geq 10KWh$ to $< 20KWh$
Low credit warning(Alarm Red LED-Flashing)	$\geq 5KWh$ to $< 10KWh$
Low credit warning(Alarm Red LED-Flashing and alarm buzzer)	$< 5KWh$
Emergency recharge credit limit	0KWh
Maximum recharge credit limit	999999.99kWh
<b>STS Key</b>	

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-05-18

Date: 2021-05-18


Supplier Group Code(SGC)	XXXXXXX (to be supplied by KPLC)
Tariff Index	1
<b>Events Parameters</b>	
Overvoltage threshold value	299V ( Phase to Neutral)
Overvoltage estimate delay	10s
Under voltage threshold value	92V ( Phase to Neutral)
Under voltage estimate delay	10s
Bypass define Threshold	10%
Bypass Enter Define Delay	30s
Overload trip threshold value	Un*Imax
Duration time of over load for disconnection	30s
Overload Exit(recovery) Define Delay	30s
Overload Recover Define Delay(after sustained overload)	30 mins
Over current trip threshold	120A
<b>MCU Display</b>	
MCU Auto -scroll interval	3s
MCU Auto -scroll sequence	-Remaining Credit balance - Total Units consumed -Date and Time -Flagged Alarms e.g. meter bypass, meter terminal cover open

#### 4.5 Interoperability Requirements

4.5.1 The Manufacturer shall produce meters that fully meet the requirements of the IEC 62055-51:2007 on Standard Transfer Specification protocol and IEC 62056-6-2:2017 on communication protocol to be provided by KPLC:


- (a) Facilitates interoperability amongst hardware, software and meters supplied by other manufacturers.

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18

- (b) Does not lock KPLC to only the bidder or any one supplier or manufacturer in its future procurement of prepayment meters, software or hardware.
- (c) The smart meters shall be interoperable with the existing KPLC Advanced Metering Infrastructure (AMI).

4.5.2 The bidder awarded the contract to supply the smart meters as per this specification shall be provided with the communication protocol encryption/decryption security key by KPLC for the meters supplied.

#### **4.6 Quality Management Systems**

- 4.6.1 The supplier shall submit a Quality Assurance Plan (QAP) that will be used to ensure that the meter design, physical properties, tests and documentation, will fulfill the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfill the requirements of ISO 9001: 2015.
- 4.6.2 Copies of quality management certifications including copy of valid and relevant ISO 9001: 2015 Certificate for international manufacturers and/or KEBS Standardization Certificate for local manufacturers shall be submitted with the tender for evaluation.

### **5 TESTS AND INSPECTIONS**

- 5.1 The meters shall be tested in accordance with the requirements of IEC 62053-21:2020, IEC 62055-31:2005 and provisions of this specification. It shall be the responsibility of the supplier to perform or to have performed the tests specified in their premise or a third party accredited laboratory.
- 5.2 The bidder shall submit copies of Type Tests Reports for each type of meter offered with the tender for technical evaluation. The Type Test Reports shall have been issued by a Third-Party testing laboratory, accredited to ISO/IEC 17025. The accreditation certificate to ISO/IEC 17025 for the same third-party testing laboratory used shall also be submitted with the tender document (all in English Language).
- 5.3 Routine and sample test reports for the meter to be supplied shall be submitted to KPLC for approval before shipment/delivery of the goods.
- 5.4 All acceptance tests as stipulated in the relevant standards shall be carried out by the supplier and shall be witnessed by KPLC Engineers before shipment.

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 20 of 51</b>	

5.5 On receipt of the goods KPLC will perform any of the tests specified in order to verify compliance with this specification.

5.6 The supplier shall conduct training in Nairobi for 20 No personnel on the use of optical and the SCSSCAA9 ports.

5.7 The supplier shall replace without charge to KPLC the meters, which upon examination, test or use; fail to meet any of the requirements in the specification.

5.8 The following tests shall be conducted on the meter as per IEC 62053-21: 2003 and other relevant standards:

**5.8.1 Tests of Insulation Properties**

5.8.1.1 Impulse Voltage Test

5.8.1.2 AC High Voltage Test

5.8.1.3 Insulation Test

**5.8.2 Test of Accuracy Requirements**

5.8.2.1 Tests on Limits of Error

5.8.2.2 Interpretation of Test Results

5.8.2.3 Test of Meter Constant

5.8.2.4 Test of Starting Conditions

5.8.2.5 Test of No-load Condition

5.8.2.6 Test of Ambient Temperature Influence

5.8.2.7 Test of Repeatability Error

5.8.2.8 Test of Influence Quantities

**5.8.3 Test of Electrical Requirements**

5.8.3.1 Test of Power Consumption

5.8.3.2 Test of Influence of Supply Voltage

5.8.3.3 Test of influence of Short-term Over-currents

5.8.3.4 Test of Influence of Self-heating

5.8.3.5 Test of Influence of Heating

5.8.3.6 Test of Influence of Immunity to Earth Faults

**5.8.4 Test for Electromagnetic Compatibility**

5.8.4.1 Radio Interference Measurement

5.8.4.2 Fast Transient Burst Test

5.8.4.3 Test of Immunity to Electrostatic Discharges

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**

#### 5.8.4.4 Test of Immunity to electromagnetic HF Fields

#### 5.8.5 Test for Climatic Influences

##### 5.8.5.1 Dry Heat Test

##### 5.8.5.2 Cold Test

##### 5.8.5.3 Damp Heat Cyclic Test

#### 5.8.6 Test for Mechanical Requirements

##### 5.8.6.1 Vibration Test

##### 5.8.6.2 Shock Test

##### 5.8.6.3 Spring Hammer Test

##### 5.8.6.4 Protection Against Penetration of Dust and Water

##### 5.8.6.5 Test of Resistance to Heat and Fire

#### 5.8.7 Functional Tests

##### 5.8.7.1 Open Cover tamper detection.

##### 5.8.7.2 Token validation test

##### 5.8.7.3 Decrementing of units when connected to Load.

##### 5.8.7.4 Automatic interrupting of the load circuit on expiry of units

##### 5.8.7.5 Test of credit balance and debit

##### 5.8.7.6 Test of disconnect of supply when credit decrement to zero

##### 5.8.7.7 Test of reconnecting supply on providing credit

##### 5.8.7.8 Test to disconnect supply if load/current exceeds the preset value of the meter

##### 5.8.7.9 Test to reconnect supply if load current falls within present value.

#### 5.8.8 Additional Tests

##### 5.8.8.1 Glow wire testing for polycarbonate material

##### 5.8.8.2 Accuracy tests in the presence of harmonics

##### 5.8.8.3 Influence of d.c and even harmonics

##### 5.8.8.4 Measurement of Total energy – Effect of Harmonics


##### 5.8.8.5 Magnetic induction of external origin (AC & DC)

#### 5.9 Minimum Testing Facilities

The manufacturer shall have the necessary minimum testing facilities for carrying out the following Routine Tests:


- (a) AC high voltage test
- (b) Insulation resistance test
- (c) Test of limits of errors

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

Doc. No.	KP1/13D/4/1/TSP/14/011-4
Issue No.	1
Revision No.	0
Date of Issue	2021-05-18
Page 22 of 51	

- (d) Test of meter constant
- (e) Test of starting condition
- (f) Test of no load condition
- (g) Repeatability of error test
- (h) Test of power consumption
- (i) Tamper conditions - as per this specification
- (j) Transportation Test.

NB: The manufacturer shall have duly calibrated Equivalent Series Resistance (ERS) meter of Class 0.5 accuracy or better.

## **6 MARKING AND PACKING**

### **6.1 Marking**

Markings shall comply with IEC 61010-1 unless otherwise specified in other parts of IEC 61557. The measuring equipment shall carry the following marking which shall be clearly readable and indelible (in English Language) on the meter and of at least 4mm figure height.

The following information shall be marked on each meter.


- (a) The Standard Transfer Specification (STS) compliant serial number, in the preferred format known as a national meter number,
- (b) The STS compliance logo,
- (c) The inscription "**Property of KPLC.**",
- (d) Name or trade mark of the manufacturer;
- (e) Wiring Connection diagram.
- (f) Country of Origin
- (g) Type/model
- (h) Meter number
- (i) Barcode comprising of meter serial number without blank spaces
- (j) Standard(s) to which the meter complies
- (k) Year and Month of Manufacture
- (l) Guarantee – 5 Years
- (m) KEBS Standardization/Diamond Mark. This is exempt for international manufacturers

Issued by: Head of Section, Standards Development


Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18



 Kenya Power	<b>THREE-PHASE WATT-HOUR SMART METER WITH SELECTABLE PREPAYMENT AND POSTPAID MODES - SPECIFICATION</b>	Doc. No.	KP1/13D/4/1/TSP/14/011-4
		Issue No.	1
		Revision No.	0
		Date of Issue	2021-05-18
		Page 23 of 51	

## 6.2 Packing

- 6.2.1 The meters shall be packaged in such a manner as to minimize damage and entry of moisture during transportation and handling.
- 6.2.2 (a) The meters shall be packed in suitable groups and / or batches with consecutive serial numbers. The barcodes of the serial numbers shall be labelled on the outer part of the carton for easy scanning. Packaging shall be done only after KPLC approval
- (b) For postpaid meters the serial numbers of the energy meters shall be provided by KPLC
- 6.2.3 The meters and UIU shall be packaged in multiples of ten unless where the number of meters in a group/batch does not make a multiple of ten and the number of meters should be packaged with an equal number of CIUs.
- 6.2.4 The number of meters packaged in a group and/or batch for handling/lifting/carrying by an operator manually shall be such that their weight does not exceed 15 kg.
- 6.2.5 The supplier shall indicate the delivery time versus quantities of each type of meter and his production capacity.

## 7 DOCUMENTATION

- 7.1 The bidder shall submit its tender complete with technical documents required by Annex A (Guaranteed Technical Particulars) for tender evaluation. The technical documents to be submitted (all in English language) for tender evaluation shall include the following:
- Fully filled clause by clause guaranteed technical particulars (GTP) signed by the manufacturer;
  - Meter drawing giving all the relevant dimensions;
  - Wiring diagrams;
  - Users and operational manuals.
  - Copies of the Manufacturer's catalogues, brochures, drawings and technical data;
  - Sales records for the last five years and at least four customer reference letters;
  - Details of manufacturing capacity and the manufacturer's experience;
  - Copies of valid Type Test Certificates and Reports by an Independent Third-Party Testing Laboratory accredited to ISO/IEC 17025; Type Test Certificates and Reports of offered meter carried out within the last Five (5) years shall be deemed valid. The test certificates

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed: 	Signed: 
Date: 2021-05-18	Date: 2021-05-18



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 24 of 51</b>	

shall bear the product serial number of meter on offer. KPLC reserves the right to demand repetition of some or all the type tests in presence of KPLC's representative, which acceptance should be submitted together with the offer. The retest results from the 3<sup>rd</sup> Party Laboratory shall be binding and not be disputed. All type test reports of the meters shall be approved by Head of Standards, KPLC, before commencement of supply. Type tests conducted in manufacturer's own laboratory and certified by testing bodies shall not be acceptable.

- i) Copy of a valid Accreditation Certificate to ISO/IEC 17025 for the Third-Party Testing Laboratory;
- j) Valid copies of ISO 9001:2015 certificate for international manufacturers and/or KEBS standardization quality mark certificate for local manufacturers.
- k) Evidence of the manufacturer having supplied a minimum of 200,000 pieces of the meter type offered to similar utilities in the past two years.
- l) Copies of DLMS/COSEM certificates
- m) Copies of STS Certificates
- n) Current e-mail addresses, fax and telephone numbers of the National / International Testing / Calibration Laboratories and Meter Certification bodies used to test the meter on offer.
- o) The supplier shall provide the test results of all the meters supplied in soft copy in a format that shall enable a quick search of a particular meter number and its results.

**NOTE:** The bidder shall complete, clearly, all the clauses in of the Schedule of Guaranteed Technical Particulars in the Annex. This shall form the basis of evaluation of the submitted tender. Failure to complete this Appendix shall render the tender non-responsive. The tenderers shall indicate the details of their offer where it is different from these requirements. Where the requirement is the same, they shall indicate what is offered. Insertions such as "noted", "agreed", "comply" etc. shall be considered as non-responsive where a specific response is called for.

7.2 The successful bidder (supplier) shall submit the following documents/details to The Kenya Power & Lighting Company for approval before manufacture:

- a) Fully filled clause by clause Guaranteed Technical Particulars (GTP) signed by the manufacturer;
- b) Design Drawings with details of low voltage measurement instruments to be manufactured for KPLC. Quality Assurance Plan (QAP) that will be used to ensure that the design, material; workmanship, tests, service capability, maintenance and documentation will fulfill the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfill the requirements of ISO 9001:2015.

<b>Issued by: Head of Section, Standards Development</b>	<b>Authorized by: Head of Department, Standards</b>
<b>Signed:</b>	<b>Signed:</b>
<b>Date: 2021-05-18</b>	<b>Date: 2021-05-18</b>



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 25 of 51</b>	

- c) The QAP Statement shall include a matrix of important raw materials and components (including the measurement and computing chips, memory chips, display modules, key electronic components and the battery) names of sub-suppliers for the raw materials, list of standards according to which the raw materials are tested and copies of test certificates in respect of bought out accessories.
- d) An outline of the proposed work and programme sequence.
- e) List of areas in manufacturing process, where stage inspections are normally carried out for quality control and details of such tests and inspections.
- f) The successful bidder shall within 30 days of placement of order, submit a matrix/list of raw materials and test certificates of the selected accessories and the names of sub-suppliers whether same or different from those furnished alongside the bids.
- g) Detailed test program to be used during factory acceptance testing;
- h) All documentation necessary for safety of the equipment as specified in IEC 61010-1:2010 clause 5.4 shall be provided with the instrument.

7.3 The supplier shall submit recommendations for use, care, storage and routine inspection/testing procedures, all in the English Language, during delivery of the meters to KPLC stores.

## **8 INFORMATION AND WARRANTY (IN CASE OF TENDER AWARD)**

### **8.1 Warranty**

- 8.1.1 The supplied meters, MCUs, UIUs and associated software/hardware shall be guaranteed by Warranty against any defects, which may develop due to faulty material, calibration, transportation or workmanship for a period of fifty-four (54) months from the date of successful commissioning certificate for KPLC or sixty (60) months from dispatch, whichever is later. All defective meters shall be replaced at the supplier's cost within one (1) month of receipt of intimation.
- 8.1.2 All software supplied shall be updated by the supplier at no extra cost while any required changes, e.g. tariff changes, statutory changes, etc. shall be implemented free of cost during the warranty period and beyond.
- 8.1.3 The successful bidder/supplier shall observe performance of their meter on site for a period of at least one (1) year and monitor accuracy of the same independently and submit a performance evaluation report of the same.

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 26 of 51</b>	

## 8.2 Samples

- 8.2.1 The tenderer shall submit three (3) MCUs and three (3) UIUs samples together with the tender documents. Samples shall not be returned to the tenderers.
- 8.2.2 The submitted meter samples shall be subjected to accuracy tests at KPLC's Meter Central Laboratory and independent third-party accredited laboratory of KPLC's choice to verify compliance with all the requirements of IEC 62053-21:2003 other requirements of this specification.
- 8.2.3 The samples of the meters offered shall be submitted together with test tokens for; different Power Limit Settings and resets for the same, Credit and Clear Credit Tokens to aid in the testing of the meters. The manufacturer might be required to provide more tokens at no extra cost.
- 8.2.4 Bidders are advised that the Laws of Kenya require that the Kenya Bureau of Standards must approve any new meter being introduced in the country. To this end, Bidders shall furnish the Bureau with 4 (four) samples of each meter type to be supplied. Bids submitted without the meter type approval from the Bureau will NOT be considered non-responsive. However, the winning Bidder must submit this approval before the signing of the supply contract.
- 8.2.5 The samples provided during tendering shall be the same as the product being delivered and this shall be confirmed with the samples and the approved drawings to verify that there is no variation of the product.

-----THIS SPACE IS LEFT BLANK-----

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed:


Date: 2021-05-18

**ANNEX A (Normative):** **Guaranteed Technical Particulars for Split Prepayment Static Meters for Active Energy Measurement** (to be filled and signed by the Manufacturer and submitted together with a sample meter, relevant copies of the Manufacturer's catalogues, brochures, drawings, technical data, sales records for previous five years, four customer reference letters, details of manufacturing capacity, the manufacturer's experience and copies of complete type test certificates and type test reports for tender evaluation, all in English Language)

Clause number	KPLC requirement		Bidder's offer (indicate full details of the offered for the prepayment meter)
	Manufacturer's Name and address		Specify
	Brand name or designation		Specify
	Country of Manufacture		Specify
	Bidder's Name and address		Specify
1.	Scope		Specify
2.	Normative References		Specify
3.	Terms, Definitions and Abbreviations		Specify
4.	<b>REQUIREMENTS</b>		
4.1	<b>OPERATING CONDITIONS</b>		
4.1.1	Operating environmental conditions	Altitude	State
		Humidity range - Rel. humidity	State
		Operating temperature	State
		Pollution category	State
		Isokeraunic levels	
4.1.2	System Characteristics	Compatible electrical system	State
		Nominal voltage and frequency	State
4.2	<b>DESIGN AND CONSTRUCTION REQUIREMENTS</b>		
4.2.1	<b>General Requirements</b> -Standards applicable		State
4.2.1.1	Meter shall be constructed as Three-phase Four-wire Direct-Connected Prepaid/Postpaid meters.		Specify
	Meter shall support both prepaid and postpaid modes.		Specify
4.2.1.2	Meter shall be of British Standard (BS) 5685-foot print for standardized mounting for asymmetrical (BS) wiring		

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-05-18

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
4.2.1.3	The meter shall have terminals with bottom entry for cables and the arrangement shall be L1L1: L2L2: L3L3: NN for 3 phase 4-wire meters	Specify
4.2.1.4	Meter base and cover shall be of non-metallic, non-hygroscopic, flame retardant, polished material having high impact-resilience and low dirt absorption properties.	Specify
4.2.1.5	Meter front cover shall be of translucent material but shall have a window (clear glass or polycarbonate) for reading the display and for observation	Specify
	Meter terminals cover shall be transparent with sealable Nickel-plated steel screws	Specify
4.2.1.6	Meter shall conform to the degree of protection of at least IP 54 as given in IEC 60529:2013.	Specify
	The terminals shall be designed to ensure protection from ingress of water and dust.	
4.2.1.7	The meter shall have a real-time clock controlled by a quartz crystal oscillator.	Specify
	It shall be possible to reset the clock without loss of billing data that shall be synchronized with the AMI system.	
4.2.1.8	The material of which the terminal block shall be capable of passing the tests given in ISO 75-1:2020.	Specify
4.2.1.9	The meter shall be for front projection mounting.	Specify
4.2.1.10	Meter shall be provided with an internal back -up battery to support the LCD display with backlight, clock and calendar in the event of an AC power failure.	Specify
	The life expectancy of the battery shall last for a minimum of 10 years.	
4.2.1.11	Meter shall be equipped with lockable/sealable push buttons where such buttons are used to program the meter parameters	Specify
4.2.1.12	The potential link of the meters shall be internal (inside the sealed part of the meter).	Specify
4.2.1.13	Meter shall have a sealing provision for terminal cover.	Specify


Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:



Signed:



Date: 2021-05-18

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
	The meter terminal cover shall be of the long type with cable entry knock-offs which shall be at least 20mm from the terminal block and shall ensure adequate coverage of all the terminals.	Specify
4.2.1.14	Meter shall have terminal cover open detection. Once the terminal cover is opened, the load shall be disconnected	Specify
4.2.1.15	Meters' terminal holes and screws shall be of moving-cage type.	Specify
	Made of brass or nickel-plated brass for high strength and good conductivity.	Specify
	The copper content in the brass shall be at least 60%.	Specify
4.2.1.16	Meter shall support double element circuit measurement (phase and neutral circuits).	Specify
4.2.1.17	The meter body dimensions shall not exceed: Height = 290mm; Width = 170mm; and Depth = 90 mm;	Specify
4.2.1.18	Meter shall have a keypad on the body of the meter for keying in the tokens and shall be IP54 compliant.	Specify
4.2.1.19	Meter body shall be ultrasonically sealed for life.	Specify
	There shall be no screws on the MCU body except for the termination of cables.	Specify
4.2.1.20	Meter shall have terminal cover open detection mechanism. Once the terminal cover is opened, the load shall be disconnected. The mechanism shall be designed to operate as in sub-clauses (a) to (c) below:	Specify
(a)	The MCU shall be supplied with loading switch in open mode and installer can open terminal cover when MCU is not activated by commissioning code (token).	Specify

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed:

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer ( <i>indicate full details of the offered for the prepayment meter</i> )
(b)	After installation of MCU, the installer will input a commission code (token) to close the loading switch and activate terminal cover open detection function. The commissioning code/token shall precede any token to be keyed into the meter to activate all functionalities of the meter. The meter shall reject any token (clear tamper token, credit token, etc.) input into the meter as long as the commissioning token has not been keyed into the meter.	Specify
(c)	After commissioning token is put into the MCU and loading switch closes, opening of the terminal cover shall lead to tamper. When MCU has power and terminal cover is opened, MCU will disconnect immediately. When MCU has no power and terminal cover is opened, MCU will detect and record the event and disconnect immediately power resumes.	Specify
4.2.1.21	MCU shall be sealed and its Printed Circuit Boards conformal coated in a manner so as not to allow malfunction due to ingress of moisture, vermin, dust, chemicals and temperature extremes	Specify
4.2.1.22	The terminals shall be of suitable rating to carry continuously I <sub>max</sub> current	Specify
4.2.1.23	Terminal holes shall be of at least 10-mm diameter and 15mm in depth.	Specify
4.2.1.24	Meter terminal cover shall have screw inserts sealable with utility wire seals.	Specify
4.2.1.25	Meter protection class shall be Class II (Double insulated) as per IEC 61140:2016 standard.	Specify
4.2.1.26	Meter shall have a non-volatile memory capable of data storage and with long-term data retention period of not less than 10 years or for the certified life of the meter or whichever is greater without an electrical supply being supplied to the meter.	Specify
4.2.1.27	Meter shall have register codes as per the list of the OBIS codes provided.	Specify

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:


Date: 2021-05-18


Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
4.2.1.28	The principal unit for the measured values shall be the kilowatt-hour (kWh) for active power and kilo volt-ampere for reactive power (kVar) with a resolution of at least 0.01 for testing purposes.	Specify
4.2.1.29	The cumulative consumption register of the meter shall <b>NOT</b> be resettable to zero	Specify
4.2.1.30	Meter shall detect significant reverse energy (SRE) when the line and load wires are swapped.	Specify
	This shall be indicated on the LCD display of the meter	Specify
4.2.1.31	Meter shall continue to operate correctly and decrement credit during SRE detection for prepaid meters and increment for postpaid meters.	Specify
4.2.1.32	Meter shall have LED indicators for testing and indication of Active power and Reactive power consumption.	Specify
4.2.1.33	The spacing between the LEDs shall be sufficient so as not disrupt the testing of the meter during the verification of the accuracy of the energy meter	Specify
4.2.1.34	The internal circuit of the meter shall be designed in a manner to delink the optical interface and the display to allow interrogation of the meter through the optical interface when the LCD display is not working	Specify
4.2.1.35	The MCU enclosure material shall be of good dielectric and mechanical strength with minimum thickness of 2.0mm. The material shall comply with IEC 60695-2-11 grow wire test.	Specify
4.2.1.35	The bidders shall specify Original Equipment Manufacturers (OEM) and any Technical Partners in the design of their meters	Specify
<b>4.2.2</b>	<b>Communication</b>	
4.2.2.1	The meter shall support bi-directional communication.	Specify
4.2.2.2	The meters shall be compliant with the DLMS/COSEM to IEC 62056 standard communication protocol.	Specify and state reference standard

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-05-18

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
	The bidder shall submit the Compliance Certificate together with the tender document for evaluation.	Specify
4.2.2.3	The meter shall have an integrated GPS module on the meter PCB for locating the meter	Specify
4.2.2.4	The meter shall be equipped with an infrared optical port compliant with the IEC 62056-21 standard for meter programming and data downloading.	Specify
4.2.2.5	The MCU shall come fitted with an SCSSCAA9 (MC171) compliant data port for programming and interrogating the meter.	Specify
4.2.2.6	The Meters shall have a modular design and have a GPRS communication module and also support other communication modules and the point at which it is placed shall be sealable. The Meter shall be able to communicate with a remote central system using a plug in modem/module, through the GPRS 3G networks and higher.	Specify
4.2.2.7	The communication module shall be hot swappable.	Specify
4.2.2.8	The communication module shall be interchangeable by the different interfaces as described in clause 4.2.2.9	Specify
4.2.2.9	The Meter shall communicate via GSM/GPRS/3G/4G/NB-IoT but shall also have a sealable slot to support field/hot swappable/ replaceable plug-in type bi-directional communication modules with easy adaptability to network interfaces with other modes of communications: G3 PLC, Radio Frequency, Wi-Fi, Fibre Optic, RS485, Modbus, IP port, Broadband PLC (BPL), Narrow band PLC (PLC), RF receiver for Long-Range WiFi (LoRa), etc. All the interfaces shall be DLSP/COSEM compliant.	Specify
4.2.2.10	The Meters shall have RS485 communication interface that include at least a 4 digital outputs, isolated from all other meter circuits with fail-safe circuitry able to withstand AC 230V for 2 minutes without damage.	Specify

**Issued by: Head of Section, Standards Development**

**Signed:**

**Date: 2021-05-18**

**Authorized by: Head of Department, Standards**

**Signed:**

**Date: 2021-05-18**

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
4.2.2.11	Meter's firmware shall be upgradable remotely and locally. Upgrading of firmware shall not stop or affect meter's metrology.	Specify
4.2.2.12(a)	The communication module shall support both SMS and GPRS modem and support the mode of: on line and on-demand on line.	Specify
(b)	The communication module shall not be powered directly from the terminals and shall have a backup battery to allow remote communication in the event of power outage.	Specify
4.2.2.13	The communication module shall support USSD, CSD communication.	Specify
4.2.2.14	Meter shall send a 'Last Gasp' power outage response when it loses power and a 'First Breath' restoration message when power is restored.	Specify
4.2.2.15	The meter shall support manual meter reading in case of loss of communication to the meter.	Specify
4.2.2.16	The meter shall work under Postpaid Mode or Prepaid Mode. The switch of mode shall be done via meter specific token or optical communication or via the system.	Specify
4.2.2.17	The meters shall be supplied together with a scanner and laptop for scanning the meters at KPLC warehouse and a laptop loaded with software for interrogating the meter data and loading commissioning and credit token during testing at our laboratory	Specify
<b>4.2.3</b>	<b>Meter Display</b>	
4.2.3.1	The meters shall have a backlight seven-segment Liquid Crystal Display (LCD) for displaying parameters and measured values.	Specify
4.2.3.2	The meter LCD shall have at least seven (7)-numerical characters comprising of selectable integers and two decimals points for energy measurement. The minimum character height shall be eight (8) mm.	Specify
4.2.3.3	The meters LCD shall be capable of displaying the current state of the relay via symbols.	Specify


Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:



Signed:




Date: 2021-05-18

Date: 2021-05-18


Clause number	KPLC requirement	Bidder's offer ( <i>indicate full details of the offered for the prepayment meter</i> )
4.2.3.4	The meters LCD shall be capable of displaying various tampering conditions of the meter.	Specify
4.2.3.5	The display parameters shall be configurable by software action.	Specify
4.2.3.6	The LCD display shall operate in at least two modes, namely, basic and extended data list display using push buttons on meter front.	Specify
4.2.3.7	Meters shall have provision for reading the meter at site even when mains power supply fails.	Specify
4.2.4	<b>Functionality Requirements</b>	
	<b>Measurement and Control Unit (MCU)</b>	
	The MCU shall measure and display the energy quantities of active power, reactive power and apparent power in both import and export modes.	Specify
	The meters shall be capable of profiling multiple channels of energy, demand (KVA, KW, KVA <sub>r</sub> ), voltage, current, power factor, harmonics, for a period of at least six (6) months for 60 minutes data intervals.	Specify
	The meter shall be able to measure the units consumed in the event of an imbalanced load or the absence of one or two phases.	Specify
	The meters shall measure Energy correctly even when the phase rotation/sequence is incorrect.	Specify
	The meters shall be capable of recording of active and reactive energy in all four (4) quadrants with up to four (4) tariffs.	Specify
	The meter shall have at least four (4) registers for energy.	Specify
	The meter shall be capable of measuring energy in security mode and also record reversed units.	Specify
	The Meter shall indicate on the LCD display reverse energy consumption	Specify
	The meter shall have capability of closing end of billing period on any selected date of the month selectable by software	Specify

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18


Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
	The meter's billing registers shall NOT be re-settable to zero.	Specify
	The meter shall have at least twelve (12) billing historical data stored in memory and retrievable by software action	Specify
	The meter shall have a load switch to disconnect the load circuit on the expiry of credit balance in the case of prepayment meters.	Specify
	The load switch shall automatically restore the load circuit after token top up for prepayment meters	Specify
	The meter load switch shall comply with the requirements given in IEC 62055-31:2005	Specify
	The meters shall have a programmable power limit setting that shall disconnect the load once exceeded and reconnect once the load falls below the set limit	Specify
	The meters shall disconnect the load if power failure is detected and connect the load after normalization	Specify
	The meters shall be able to indicate absence or presence of continuous power by use of a Light Emitting Diode (LED).	Specify
	The MCU shall have an LED indicator to show the rate of consumption. The pulse rate shall be proportional to current rate of consumption.	Specify
	The MCU shall have an LED to indicate the presence of an alarm of any registered event on the meter.	Specify
	The MCU shall have a self-diagnostic feature to diagnose the status of the functions of the meter.	Specify
	The MCU shall have a Liquid Crystal Display (LCD) for numeric display and language independent pictograms to identify operational features with backlight. The LCD shall have a wide viewing angle of 45 deg. to 60 deg. with, up to one-meter distance.	Specify
4.2.3.1.14	The Live and Neutral shall be DC immune complying with requirements of IEC 62052-11:2020 and IEC 62055-31:2005.	Specify

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18


Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18


Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
4.2.3.1.6	The MCU shall come fitted with an SCSSCAA9 (MC171) compliant data port for programming and interrogating the meter. Two (2) sets of data interrogating and programming probes and software (1 each for optical and SCSSCAA9 ports) shall be provided with the meter sample for evaluation. For the winning bidders, each delivery of 100,000 meters shall have 50 sets of probes and read only software for use with the optical and the SCSSCAA9 ports.	Specify
4.2.3.1.7	The MCU shall be supplied together with a plastic card of dimension 60mm x 40 mm (length x height) indicating the meter number. A tolerance of $\pm 1$ mm will be acceptable. The meter serial number shall be engraved on the card together with its bar code version. No random redundant digits shall be added to the meter number.	Specify
4.2.3.1.8	The MCU shall be with Nil units pre-loaded (i.e. 0 (Zero) kWh.	Specify
<b>4.2.5</b>	<b>Time-of-use tariff measurements</b>	
	The meters shall be capable of measuring and displaying time-of-day active and reactive energy consumption up to four tariff registers.	Specify
	The meters shall be capable of measuring and displaying time-of-day demand (kW and kVA) consumption up to four tariff registers.	Specify
	Each tariff register shall be set to operate over defined time periods during a 24-hour day.	Specify
	The meters shall have at least two seasons and four day types namely weekday, Saturday, Sunday and Special/Holiday with switching times set independently.	Specify
	The meters shall have at least forty (40) special days to take care of national holidays, world days and Easter holidays.	Specify
<b>4.2.6</b>	<b>Demand measurements</b>	

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
	The meters shall be capable of measuring and displaying active, reactive and apparent demand consumption in both import and export modes.	Specify
	The meters shall display demand values and their time and date stamps.	Specify
	The meters shall measure demand correctly even when the phase rotation/sequence is incorrect.	Specify
	The meter shall have at least four (4) registers for demand.	Specify
	The meters shall have a capability of closing end of billing period on any selected date of the month selectable by software.	Specify
	The meters shall have at least twelve (12) billing historical data stored in memory and retrievable by software action. The current and billing/historical data shall be available on meter display for reading and billing purposes.	Specify
4.2.7	<b>Instrumentation data measurements</b>	Specify
	The meters shall be capable of displaying instrumentation data namely instantaneous phase voltages and currents, phase angles, and power factor.	Specify
	The meters shall be capable of measuring and displaying instantaneous power (active, reactive and apparent).	Specify
	The meters shall be capable of measuring and displaying average power factor for the current and the previous billing months.	Specify
	The meters shall be capable of continuous display of the presence or absence of individual phase voltages.	Specify
	The meter shall have diagnostics to alert of any abnormal three phase power condition, such as: over/under voltage, missing voltage, missing current, improper meter vectors for service, reverse power flow, etc.	Specify
4.2.8	<b>Load profiling</b>	


Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:



Signed:




Date: 2021-05-18

Date: 2021-05-18


Clause number	KPLC requirement	Bidder's offer ( <i>indicate full details of the offered for the prepayment meter</i> )
	The meters shall be capable of profiling multiple channels of energy, demand (kVA, kW, kVAr), voltage, current, power factor, harmonics, for a period of at least six (6) months for 60 minute intervals.	Specify
	The load profile integration period shall be programmable from one (1) minute up to a maximum of sixty (60) minutes.	Specify
<b>4.2.9</b>	<b>Power Quality Analysis</b>	
	The meter shall collect and record basic power quality information – overcurrent, total no. of alarms, power outages, voltage and current, average power factor and line frequency, etc.	Specify
	The meter shall be able to provide voltage sag and swell detection.	Specify
	The meters shall provide Total Harmonic Distortion (THD) event detection at least up to the 10th harmonic with analysis for unusual system conditions.	Specify
<b>4.3</b>	<b>Security features</b>	

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18

The meters shall be capable of event recording and communication, which shall include but not be limited to the following:

- q) Power ups and power downs with date and time stamp;
- r) Individual phase failure, with date and time stamps;
- s) Over- and under-voltages based on a pre-set threshold with date & time stamp;
- t) Battery voltage status (if applicable);
- u) Memory status;
- v) Meter errors,
- w) Date and time of last programming/parameterization;
- x) Date and time of the last end of billing period;
- y) Firmware upgrades
- z) Prepayment events
- aa) Terminal cover removal, even during a power failure
- bb) Main meter cover removal, even during a power failure
- cc) Communications removal
- dd) Magnetic detection, at least 0.5 mT
- ee) Bypassing neutral
- ff) Interchanging incoming and outgoing leads

The LCD shall display events that have occurred. The events displayed shall include but not be limited to the following:

- j) Meter errors
- k) Phase failures
- l) Battery voltage status (if applicable)

Specify

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed:

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
	m) Alarms n) Warning messages o) Prepayment mode p) Terminal cover removal q) Communications removal r) Magnetic detection, at least 0.5 mT	
4.4	<b>Electrical Requirements</b>	Specify
4.4.1	The meter shall be operated from mains with reference values of 3 x 230/415V, 50 Hz $\pm$ 10 %, with a load switching voltage range from 0.4Un to 1.3Un phase to neutral	Specify
4.4.2	The load switch shall be of bi-stable type designed and manufactured in accordance with IEC 61810- 1, as well as meet the overload and short circuit requirement of IEC 62052-11 / 62055-31:2005. The load switch shall interrupt the supply when the voltage is below 0.4 Un and above 1.3Un phase to neutral	Specify
4.4.3	The load switch shall automatically restore supply within a minute when the voltage falls within 0.4 Un – 1.3 Un phase to neutral.	Specify
4.3.4	The meters shall be connectable for 2-wire systems, a permanent connection drawing of which shall be printed on the meter body. Stickers of any kind shall not be accepted.	Specify
4.4.5	The meter shall have Reference Standard Electrical Design Parameters as in Table 2 below.	Specify
4.4.5	<b>Summary of electrical parameters as per table 1 of specification</b>	Specify
(a)	Meter accuracy class	Specify class and reference standard
(b)	Rated Nominal Voltage (Un)	Specify
(c)	Load switching voltage range	Specify
(d)	Maximum Voltage Circuit burden (W and VA)	Specify

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2021-05-18

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
(e)	Base Reference Current, Ib	Specify
(f)	Maximum Current circuit burden (VA)	Specify
(g)	Maximum Current I <sub>max</sub> (A)	Specify
(h)	Protective class	Specify class and reference standard
(i)	Accurate Metering Range	Specify
(j)	Starting Current (as a percentage of Ib)	Specify
(k)	Running with no-load	Specify
(l)	Short Circuit current (as a function of I <sub>max</sub> )	Specify
(m)	Meter constant	Specify
(n)	Disconnection device	Specify type and current rating
(o)	Insulation class	Specify and reference standard
(p)	Insulation Level (kV)	Specify and reference standard
(q)	Overvoltage withstand (VAC for 48 hours)	Specify and reference standard
(r)	Voltage Impulse Withstand (KV)	Specify withstand value and reference standard
(s)	Current Impulse withstand (kA/microsecs)	Specify withstand value and reference standard
(t)	Lightning Surge Withstand	Specify withstand value and reference standard
(u)	EMC-Electrostatic discharge (kV air discharge)	Specify rating and reference standard
(v)	Immunity to HF Fields	Specify rating and reference standard
(w)	Immunity to Fast Transient Bursts	Specify rating and reference standard
(x)	Immunity to Radio interference	Specify rating and reference standard

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2021-05-18

Date: 2021-05-18

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
(y)	Rated impulse withstand voltage of PLC (kV)	Specify withstand value and reference standard
(z)	Insulation level of PLC (kVrms)	Specify withstand value and reference standard
(aa)	Communication Protocol	Specify
(bb)	Communication Range of PLC	Specify
4.4.6	Default Factory Parameters settings	Specify
	<b>Basic Parameters</b>	
(a)	Rated Voltage	Specify
(b)	Basic Current (Ib)	Specify
(c)	Maximum Current (Imax)	Specify
(d)	Meter Constant	Specify
(e)	Frequency	Specify
(f)	Load Rating	Specify
(g)	Time zone	Specify
	<b>Measurement Configuration</b>	
(h)	Active	Specify
(i)	Reactive	Specify
	<b>Prepayment Parameters</b>	
(j)	Factory default payment mode	Specify
(k)	Pre-load credit	Specify
(l)	Low credit warning (Alarm green LED-Permanent)	Specify
(m)	Low credit warning (Alarm Red LED-Permanent)	Specify
(n)	Low credit warning (Alarm Red LED-Flashing)	Specify
(o)	Low credit warning (Alarm Red LED-Flashing and alarm buzzer)	Specify
(p)	Emergency recharge credit limit	Specify
(q)	Maximum recharge credit limit	Specify
	<b>Event Parameters</b>	
(r)	Overvoltage threshold value	Specify
(s)	Overvoltage estimate delay	Specify
(t)	Under voltage threshold value	Specify
(u)	Under voltage estimate delay	Specify

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:


Signed:

Date: 2021-05-18

Date: 2021-05-18


Clause number	KPLC requirement	Bidder's offer ( <i>indicate full details of the offered for the prepayment meter</i> )
(v)	Bypass define Threshold	Specify
(w)	Bypass Enter Define Delay	Specify
(x)	Overload trip threshold value	Specify
(y)	Duration time of over load for disconnection	Specify
(z)	Overload Exit(recovery) Define Delay	Specify
(aa)	Overload Recover Define Delay(after sustained overload)	Specify
(bb)	Over current trip threshold	Specify
<b>4.5</b>	<b>Interoperability Requirements</b>	
4.5.1	The meter's applicable standards	Specify
(a)	Interoperability of the meter on offer among hardware, software and meters supplied by other manufacturers	Specify
(b)	Non-proprietary technology that does not lock KPLC to only one bidder or any one manufacturer in its future procurement of software, hardware or meters	Specify
(c)	Meter interoperable with the existing KPLC smart metering management system. The bidder shall be able to demonstrate this capability before award.	Specify
4.4.2	Provision of Communication protocol Encryption/decryption key	Provide
<b>4.6</b>	<b>Quality Management System</b>	
4.6.1	Quality Assurance Plan	Provide
4.6.2	Copy of valid ISO 9001:2015 Certificate for international manufacturers and/or KEBS standardization certificate for local manufacturers	Provide
<b>5.</b>	<b>TESTS AND INSPECTIONS</b>	
5.1	Test standards and responsibility of carrying out tests	Specify
5.2	Copies of valid Type Test Reports and 3 <sup>rd</sup> Party testing lab accreditation certificate submitted with tender	Provide
5.3	Routine and sample test reports to be submitted by supplier to KPLC for approval before shipment	Provide
5.4	Acceptance tests to be witnessed by KPLC Engineers at factory before shipment	Provide

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-05-18

**THREE-PHASE WATT-HOUR SMART METER WITH SELECTABLE PREPAYMENT AND POSTPAID MODES - SPECIFICATION**

Doc. No.	KP1/13D/4/1/TSP/14/011-4
Issue No.	1
Revision No.	0
Date of Issue	2021-05-18
Page 44 of 51	

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
5.5	KPLC to perform any of the tests independently in order to verify compliance with this specification	Comply
5.6	Training of 20No. KPLC staff on the use of optical and the SCSSCAA9 ports.	Comply
5.7	Supplier to replace without charge to KPLC meters which upon examination, test, or use, fail to meet any requirements in the specification	Comply
5.8	Required Type Tests and Routine Acceptance Tests	Specify
5.9	Minimum testing facilities	Specify
6	<b>MARKING AND PACKING</b>	
6.1	Marking as per specification	Specify
6.2	Packing as per specifications	Specify
7	<b>DOCUMENTATION</b>	
7.1	Documents to be submitted with GTPs for tender evaluation	Comply
7.2	Documents to be submitted to KPLC for approval before manufacture (if tender awarded)	Comply
8	<b>INFORMATION AND WARRANTY</b>	
8.1	Fifty four (54) months warranty from date of successful commissioning certificate for KPLC or Sixty (60) months warranty from the date of dispatch whichever is later	Specify
8.1.2	Software supplied shall be updated by the supplier at no extra cost while any required changes, e.g. tariff changes, statutory changes, etc. shall be implemented free of cost during the warranty period and beyond.	Specify
8.1.3	The successful bidder/supplier shall observe performance of their meter on site for a period of at least one (1) year and monitor accuracy of the same independently and submit a performance evaluation report of the same.	Specify
8.2	<b>Samples</b>	Specify
8.2.1	The tenderer shall submit Three (3) MCUs samples together with the tender documents (N.B. Samples shall not be returned to the tenderers).	Provide

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed:

Date: 2021-05-18



**THREE-PHASE WATT-  
HOUR SMART METER  
WITH SELECTABLE  
PREPAYMENT AND  
POSTPAID MODES  
- SPECIFICATION**

<b>Doc. No.</b>	<b>KP1/13D/4/1/TSP/14/011-4</b>
<b>Issue No.</b>	<b>1</b>
<b>Revision No.</b>	<b>0</b>
<b>Date of Issue</b>	<b>2021-05-18</b>
<b>Page 45 of 51</b>	

Clause number	KPLC requirement	Bidder's offer (indicate full details of the offered for the prepayment meter)
	The submitted meter samples shall be subjected to type and routine tests at KPLC's Meter Central Laboratory and also a third-party accredited laboratory to verify the requirements of IEC 62053-21:2020 and to verify responsiveness to other requirements of this specification.	Comply
8.2.2	Sample of meter offered to be submitted together with test tokens for different power limit settings and resets for the same, credit and clear credit tokens to aid in the testing of the meters. The manufacturer may be required to provide tokens at no extra cost	Provide

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-05-18

Authorized by: Head of Department, Standards

Signed:

Date: 2021-05-18

