



NOTE: CENTRE INSULATOR TO BE FITTED AS SHOWN DOTTED AT ALTERNATE POLES.

ITEM	QTY.	DESCRIPTION
1	1	CONCRETE POLE
2	1	L 70x70x9.5 CROSSARM
3	2	L 50x50x8 V-ARM BRACE SET
4	3	COMPOSITE PIN INSULATOR
5	2	CLAMP SET TYPE 2
6	2	M20x40 BOLT W/FLAT & 1NUT
7	1	DANGER PLATE
8	1	POLE NUMBER
9	-	CONDUCTOR
10	4	CLAMP SET TYPE 1
11	4	3PH LV FITTINGS SETS

CONCRETE POLES

H (m)	h (m)
12	1.8
14	2
15	2.1

APPROVED BY	NAME	DATE	SGN

ENGINEER I/C	REF.	REVISION	DATE	SGN	CHECKED	DATE

11KV INTERMEDIATE WITH 3PH ASSEMBLY

SHEET 17/C

K.P.& L.Co LTD

SK. No. 11257